




Bottom View




CH401 Front View




Top View



ANG404 Front View



ANG407 Front View



ANG408 Front View

NOTES:

- 1) ASTM 325 ERECTION BOLTS
- 2) ALL HOT DIP GALVANIZED AFTER FABRICATION (ASTM A123)
- 3) ALL HOLES 11/16" DIA. FOR 5/8" DIA. BOLTS UNLESS NOTED
- 4) PIECE MARK STAMPED INTO METAL WITH NOT LESS THAN 3/8" HIGH CHARACTERS BEFORE GALVANIZING
- 5) ALL WELDING ELECTRODES SHALL BE E7021
- 6) EDGE DISTANCE 1" UNLESS NOTED

PRELIMINARY - DO NOT USE FOR CONSTRUCTION	NO.	REVISIONS	DATE	PUBLIC WORKS COMMISSION OF THE CITY OF FAYETTEVILLE FAYETTEVILLE, NORTH CAROLINA		
	0	ISSUED FOR BIDS	08/02/21			
				BLACK AND DECKER 69 TO 15 X 25 kV SUBSTATION SWITCH STAND		
				Booth & Associates, LLC <small>5811 Glenwood Avenue Raleigh, NC 27612 CONSULTING ENGINEERS NC F-0221</small>		
				DWN. RLT	DATE: 08/02/21	DWG. NO. SS-6 12502_SWITCH
				CKD. MJM	APPD. MJM	
				SCALE: NONE	© 08/21	
© 08/21						