




G201 Front View




Top View




ANG201 Front View




Front View




ANG209 Top View




Front View



ANG210 Top View




Top View



ANG216 Front View

BILL OF MATERIAL				
POS. NO.	QTY	DESC.	LENGTH	WEIGHT
G201	6	FOR ONE GROUP G201:		
ANG201	1	L4x3x1/4	8'-8"	50.27
ANG209	1	L4x3x1/4	1'-5 1/16"	8.25
ANG210	1	L4x3x1/4	1'-5 1/16"	8.25
ANG216	3	L4x3x1/4	6"	8.70
BLACK WEIGHT:			75.47 LBS.	
GALVANIZED WEIGHT:			3.01 LBS.	
TOTAL WEIGHT:			78.99 LBS.	



G201 Right View

- NOTES:
- 1) ASTM 325 ERECTION BOLTS
  - 2) ALL HOT DIP GALVANIZED AFTER FABRICATION (ASTM A123)
  - 3) ALL HOLES 11/16" DIA. FOR 5/8" DIA. BOLTS UNLESS NOTED
  - 4) PIECE MARK STAMPED INTO METAL WITH NOT LESS THAN 3/8" HIGH CHARACTERS BEFORE GALVANIZING
  - 5) ALL WELDING ELECTRODES SHALL BE E7021
  - 6) EDGE DISTANCE 1" UNLESS NOTED

PRELIMINARY - DO NOT USE FOR CONSTRUCTION	NO.	REVISIONS	DATE	PUBLIC WORKS COMMISSION OF THE CITY OF FAYETTEVILLE FAYETTEVILLE, NORTH CAROLINA		
	0	ISSUED FOR BIDS	08/02/21			
				BLACK AND DECKER 69 TO 15 X 25 kV SUBSTATION URD STAND DETAILS		
				Booth & Associates, LLC 5811 Glenwood Avenue   Raleigh, NC 27612   CONSULTING ENGINEERS INC F-0221		
				DWN. RLT	DATE 08/02/21	DWG. NO.
				CKD. MJM	APPD. MJM	URD-2
				SCALE: NONE	© 08/21	15202_URD
© 08/21						