




BILL OF MATERIAL				
POS. NO.	QTY	DESC.	LENGTH	WEIGHT
<b>G501</b>	<b>3</b>	<b>FOR ONE GROUP G501:</b>		
ANG507	1	L3x3x1/4	3"	1.23
BASE503	1	Plate 1'-3"x1"	1'-3"	63.93
CH508	1	MC8x22.8	8"	15.20
PL502	1	PL 10"x1/2"	10"	14.21
ST501	1	HSS8x8x3/16	20'-4 1/2"	399.55
BLACK WEIGHT:			494.12	LBS.
GALVANIZED WEIGHT:			19.76	LBS.
TOTAL WEIGHT:			513.88	LBS.




Top View



G501 Front View




ANG507 Front View



CH508 Front View

- NOTES:
- 1) ASTM 325 ERECTION BOLTS
  - 2) ALL HOT DIP GALVANIZED AFTER FABRICATION (ASTM A123)
  - 3) ALL HOLES 11/16" DIA. FOR 5/8" DIA. BOLTS UNLESS NOTED
  - 4) PIECE MARK STAMPED INTO METAL WITH NOT LESS THAN 3/8" HIGH CHARACTERS BEFORE GALVANIZING
  - 5) ALL WELDING ELECTRODES SHALL BE E7021
  - 6) EDGE DISTANCE 1" UNLESS NOTED



PL502

BASE503

PRELIMINARY - DO NOT USE FOR CONSTRUCTION	NO.	REVISIONS	DATE	PUBLIC WORKS COMMISSION OF THE CITY OF FAYETTEVILLE FAYETTEVILLE, NORTH CAROLINA		
	0	ISSUED FOR BIDS	08/02/21			
				BLACK AND DECKER 69 TO 15 X 25 kV SUBSTATION 1Ø BUS STAND		
				Booth & Associates, LLC <small>5811 Glenwood Avenue · 1 Raleigh, NC 27612 · CONSULTING ENGINEERS NC F-0221</small>		
				DWN. RLT	DATE 08/02/21	DWG. NO. BUS-1 12502_BUS
				CKD. MJM	APPD. MJM	
				SCALE: NONE	© 08/21	
© 08/21						