



WADE R. FOWLER, JR., COMMISSIONER
EVELYN O. SHAW, COMMISSIONER
RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
ELAINA L. BALL, CEO/GENERAL MANAGER

FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

January 20, 2022

TO: All Prospective Bidders

FROM: Trent Ensley, Procurement Manager

SUBJECT: ADDENDUM NO. 2
PWC2122030 – RFP FOR LIFT STATION #26 – GOLDEN CREEK
STANDBY POWER GENERATOR

1. The Specifications and Bid Documents are hereby modified or clarified per the attached documents.
2. The foregoing changes or clarifications shall be incorporated in the original Bid Documents and a signed copy of this Addendum No. 2 shall accompany the bid to acknowledge the bidder's receipt and familiarity with the changes and/or clarifications.

TE: tke

Acknowledgement:

Company_____

By_____

Date_____



WADE R. FOWLER, JR., COMMISSIONER
EVELYN O. SHAW, COMMISSIONER
RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
ELAINA L. BALL, CEO/GENERAL MANAGER

FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

January 20, 2022

TO: Prospective Bidders
FROM: Trent Ensley, Procurement Manager
SUBJECT: **ADDENDUM No. 2**
PWC2122030: Lift Station #26 – Golden Creek Standby Power Retro-fit



NOTICE TO CONTRACTORS:

This Addendum shall become a part of the Contract Documents for the above projects as they apply.

Each Contractor shall be responsible for notifying their subcontractors of the contents of this addendum.

Revised or newly issued drawings contained in this addendum shall supersede and take precedence over any conflicting information in the original drawings. Modified or newly issued specifications contained in this addendum shall supersede and shall take precedence over any conflicting information in the original specifications.

Item #1: The deadline for submission of proposals is amended as follows:

GENERAL TERMS AND CONDITIONS

1. In “Paragraph B. Bid Proposal”, change the deadline for submittal of proposals from **“5:00 pm, Friday, January 21, 2022”** to **“5:00 pm, Friday January 28, 2022”**.

Item #2: Questions received from prospective bidders are addressed as follows:

1. Can you provide some clarity regarding the owner provided equipment; will the owner provide all equipment? I know the owner will be providing the 60kW Generator and Pump Control Panel, but will they also provide the ATS, CP, CB, DSU, DS, A/B, A/H, fuel, rigging, light fixture, wetwell floats and probe? Panel LP is existing, who is the manufacturer (assuming we are responsible for adding a 1P 20A breaker to this panel)? Please advise, thanks.

Bidders' attention is directed to plan sheet E-3, note #8 under "DEMOLITION & REVISED ELECTRICAL NOTES". Per note #8, the Pump Control Panel / RTU will be furnished by the Owner (PWC) and installed by the Contractor.

Per the project specifications, all remaining equipment including the 60kW Generator, Automatic Transfer Switch, appurtenances and incidentals will be provided by the Contractor.

The existing Panel LP in the building is a Square D, QO Load center, Cat. No. QO6-12L100.

END ADDENDUM #2