



WADE R. FOWLER, JR., COMMISSIONER
EVELYN O. SHAW, COMMISSIONER
RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
MARION J NOLAND, INTERIM CEO/GENERAL MANAGER

FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

September 22, 2022

To: Potential Surplus Transformer Bidders
From: Paula Eckard, Supply Chain Analyst
CC: Elbert Norris, Apparatus Repair Shop Supervisor
Subject: Bid No. PWC2223009 for Surplus Transformer Shipment # 635

The Fayetteville Public Works Commission hereinafter referred to as Commission manages and controls various pieces of equipment. As the legal title holder of equipment, the Commission has approved the sale of equipment by sealed bid. The surplus transformer shipment #635 consists of one (1) lot of 40 pad mount transformers, totaling 2175 KVA.

The Commission will accept sealed bids for this equipment until 2:00 p.m., Thursday, October 6, 2022, at Fayetteville PWC, PO Box 1089, Fayetteville, NC 28301, all bids received shall be opened in public and the amount of each bid announced and recorded. In order for your bid to be accepted the bid number must be written on the outside of the sealed envelope.

In order for a bid to be considered, the bidder must be pre-qualified to dispose of transformers. Bidding information may be viewed online at <https://www.faypwc.com/bids/>

The Commission reserves the right to withdraw the equipment from sale at any time and the right to reject any and all bids, waive all informalities concerning a bid or award a bid to the highest responsible bidder.

The successful bidder must remit payment within 30 calendar days from the bid award. The PWC Supply Chain Department accepts wire transfers, certified checks, or money orders as forms of payment. All items must be picked up from the PWC within 10 business days after receipt of payment. The PWC does not provide any loading, packing, shipping, and/or labor assistance for pickups. The successful bidder must arrange and perform all necessary labor to load, pack, ship, and/or remove the items. Property may be removed between the hours of 9:00 a.m. to 12:00 p.m. or 1:00 p.m. to 4:00 p.m. Monday through Friday, excluding State holidays

Inquiries concerning the bidding process may be made to paula.eckard@faypwc.com, if you have prequalification or technical questions about the units offered, please contact elbert.norris@faypwc.com.



Surplus Transformer Shipment Lot 635

Due October 6, 2022

Bid Pricing Form

Bidders Information

Bidders Name: _____

Street Address: _____

Telephone Number: _____

Email: _____

Print Name and Title: _____

Bidders Authorized Signature: _____

Date: _____

Pricing

LOT	QTY <i>(LOT KVA TOTAL)</i>	UNIT COST	EXTENDED COST
635	2175		

Shipment

Surplus List

4/28/2017

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu.	Date O.S.	Co #	YMFG	2022
1	851060567	50	1-295-620	7200	240/120	G	PAD	755	2101156-02	<1.0	RT	11/2/21	023276	1985	37
2	78B653259	50	1-295-620	7200	240/120	G	PAD	990	2101156-02	<1.0	WH	11/2/21	018784	1978	44
3	851060564	50	1-295-620	7200	240/120	G	PAD	755	2101156-02	<1.0	RT	11/2/21	023275	1985	37
4	86JF690215	50	1-295-620	7200	240/120	G	PAD	926	2101156-02	<1.0	WH	11/2/21	024126	1986	36
5	96189-4684	50	1-295-620	7200	240/120	G	PAD	800	2101156-02	<1.0	HI	11/2/21	024045	1984	38
6	33U2819830	50	1-295-630	7.2x14.4	240/120	G	PAD	950	2101156-02	<1.0	ER	11/2/21	028125	1991	31
7	33U2819840	50	1-295-630	7.2x14.4	240/120	G	PAD	950	2101156-02	<1.0	ER	11/2/21	028135	1991	31
8	86JK781219	75	1-295-635	7200	240/120	G	PAD	1072	2101156-02	<1.0	WH	11/2/21	024380	1986	36
9	86JK782112	75	1-295-635	7200	240/120	G	PAD	1072	2101156-02	<1.0	WH	11/2/21	024388	1986	36
10	90608325331	75	1-295-640	7.2x14.4	240/120	G	PAD	1195	2101156-02	<1.0	ER	11/2/21	042938	2006	16
11	78JB652149	50	1-295-620	7200	240/120	G	PAD	990	2101156-02	<1.0	WH	11/2/21	018782	1978	44
12	85JK528057	50	1-295-620	7200	240/120	N	PAD	926	2204778-01	<1.0	WH	10/21/21	023642	1985	37
13	871092383	50	1-295-630	7.2x14.4	240/120	N	PAD	895	2205241-01	<1.0	RT	10/27/21	024701	1987	35
14	60307668459	50	1-295-630	7.2x14.4	240/120	G	PAD	936	2206190-01	<1.0	ER	11/23/21	040108	2003	19
15	86JF692104	75	1-295-635	7200	240/120	G	PAD	1072	2101156-02	<1.0	WH	11/2/21	024167	1986	36
16	8.41E+08	50	1-295-620	7200	240/120	G	PAD	765	2204446-03	<1.0	RT	11/18/21	022741	1984	38
17	92LN128010	100	1-295-655	7.2x14.4	240/120	G	PAD	1326	2206016-01	<1.0	CP	11/17/21	029325	1992	30
18	941057483	50	1-295-630	7.2x14.4	240/120	G	PAD	900	2209813-01	<1.0	CP	2/24/22	031651	1994	28
19	20107297241	100	1-295-655	7.2x14.4	240/120	G	PAD	1449	2206424-01	<1.0	ER	11/25/21	037619	2001	21
20	3737845194	50	1-295-630	7.2x14.4	240/120	G	PAD	850	2001291-03	<1.0	HI	12/14/21	032369	1994	28
21	1666231294	75	1-295-640	7.2x14.4	240/120	G	PAD	1199	2001291-03	<1.0	HI	12/14/21	031156	1994	28
22	73L621081	25	1-295-605	7200	240/120	G	PAD	880	2205690-03	<1.0	WH	2/11/22	018802	1973	49
23	2001291-03	50	1-295-630	7.2x14.4	240/120	G	PAD	900	2001291-03	<1.0	CP	12/14/21	053721	1994	28
24	901024471	50	1-295-630	7.2x14.4	240/120	G	PAD	800	2205677-01	<1.0	CP	2/17/22	027037	1990	32
25	941133330	25	1-295-610	7.2x14.4	240/120	G	PAD	650	2001291-03	<1.0	CP	12/14/21	032274	1994	28
26	73L622040	25	1-295-605	7200	240/120	G	PAD	880	2205679-01	<1.0	WH	3/2/22	018860	1973	49

Shipment #

Surplus List

4/28/2017

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu.	Date O.S.	Co #	YMFG	2022
27	1065170295	50	1-295-630	7.2x14.4	240/120	G	PAD	850	2203975-03	<1.0	HI	3/16/22	032377	1995	27
28	1257180594	75	1-295-640	7.2x14.4	240/120	G	PAD	1199	2201131-02	<1.0	HI	3/15/22	031015	1994	28
29	941016389	25	1-295-610	7.2x14.4	240/120	G	PAD	650	2001291-03	<1.0	CP	12/14/21	030925	1994	28
30	941016373	25	1-295-610	7.2x14.4	240/120	G	PAD	650	2001291-03	<1.0	CP	12/14/21	030923	1994	28
31	1257210594	75	1-295-640	7.2x14.4	240/120	G	PAD	1199	2201131-02	<1.0	HI	3/15/22	031024	1994	28
32	N468952YEUA	100	1-295-645	7200	240/120	G	PAD	1349	2209304-01	<1.0	GE	2/13/22	053722	1982	40
33	901024443	50	1-295-630	7.2x14.4	240/120	G	PAD	800	2001291-03	<1.0	RT	12/14/21	027170	1990	32
34	931050309	50	1-295-630	7.2x14.4	240/120	G	PAD	850	2001291-03	<1.0	CP	12/14/21	029959	1993	29
35	60808724917	50	1-295-630	7.2x14.4	240/120	G	PAD	1020	2210424-01	<1.0	ER	3/8/22	046114	2006	16
36	931119827	50	1-295-630	7.2x14.4	240/120	G	PAD	900	2001291-03	<1.0	CP	12/14/21	030539	1993	29
37	74H803072	50	1-295-625	14400	240/120	G	PAD	1020	2203975-03	<1.0	WH	3/16/22	018793	1974	48
38	901027038	50	1-295-630	7.2x14.4	240/120	G	PAD	945	2209535-01	<1.0	RT	2/18/22	027176	1990	32
39	18A5275807	50	1-295-630	7.2x14.4	240/120	G	PAD	905	2001291-03	<1.0	ER	12/14/21	034028	1997	25
40	941133310	25	1-295-610	7.2x14.4	240/120	G	PAD	650	2001291-03	<1.0	CP	12/14/21	032275	1994	28

Total KVA = 2175.0

Total Lbs= 37870

AVG= 32

Total Units >= 30 years 22
 Total Units >=20 and <= 30 15
 Total Units < 20 3
 Total = 40

25 Kva total=	150
37.5 Kva total=	0
50 Kva total=	1200
75 Kva total=	525
100 Kva total=	300
167 Kva total=	0

Total KVA 2175.0

1-295-605	2
1-295-608	0
1-295-610	4
1-295-613	0
1-295-615	0
1-295-620	8
1-295-621	0
1-295-625	1
1-295-630	15
1-295-635	3

N Total Bad Unit= 2
 G Total Operational Units= 38

 Total= 40

Mfg Totals
 AC 0
 ABB 0
 C.E. 0

Shipment #

Surplus List

4/28/2017

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu.	Date O.S.	Co #	YMFG	2022
-----	---------	-----	--------------	-------------	-------------	-----------	------	--------	------------	-----	-------	-----------	------	------	------

				1-295-640	4				C.M.	0					
				1-295-645	1				COOPER	10					
				1-295-650	0				ERMCO	7					
				1-295-655	2				GE	1					
				1-295-656	0				HOWARD	6					
				1-295-670	0				KUHLMAN	0					
				1-295-690	0				MCGRAW EDISON	0					
				1-295-695	0				RTE	6					
									WEST	10					
									PAUW	0					
				Total#											
				Units	40										
									Total=	40					

Total# 25 Kva =	6
Total# 37.5 Kva =	0
Total# 50 Kva =	24
Total# 75 Kva =	7
Total# 100 Kva =	3
Total# 167 Kva =	0

Total	40
--------------	-----------

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information		
Serial Number	851060567	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153866	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

2

Nameplate Data				Equipment Information		
Serial Number	78B653259	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date		11/17/2021
Barcode Sample Number		00153874
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

3

Nameplate Data				Equipment Information		
Serial Number	851060564	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153868	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

4

Nameplate Data				Equipment Information	
Serial Number	86JF690215	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/17/2021	
Barcode Sample Number	00153869	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

5

Nameplate Data				Equipment Information		
Serial Number	96189-4684	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153875	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

6

Nameplate Data				Equipment Information		
Serial Number	33U2819830	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153872	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

7

Nameplate Data				Equipment Information		
Serial Number	33U2819840	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153863	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

8

Nameplate Data				Equipment Information		
Serial Number	86JK781219	Unit ID	PAD	Top Valve (in)		Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)		Paint Condition
Year Manufactured		Primary KV		Conservator Tank		Bushings Enclosed
Gallons		KVA Rating	75	Leaks		Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized		Compartments
Substation Location	Apparatus	Breathing Configuration				

Sample Date		11/17/2021
Barcode Sample Number		00153865
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

9

Nameplate Data				Equipment Information		
Serial Number	86JK782112	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	75	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153871	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

10

Nameplate Data				Equipment Information		
Serial Number	90608325331	Unit ID	PAD	Top Valve (in)		Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)		Paint Condition
Year Manufactured		Primary KV		Conservator Tank		Bushings Enclosed
Gallons		KVA Rating	75	Leaks		Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized		Compartments
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153870	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information		
Serial Number	78JB652149	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00153867	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

12

Nameplate Data				Equipment Information		
Serial Number	85JK528057	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date		11/17/2021
Barcode Sample Number		00151228
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

13

Nameplate Data				Equipment Information		
Serial Number	871092383	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	11/17/2021	
Barcode Sample Number	00151236	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

14

Nameplate Data				Equipment Information		
Serial Number	60307668459	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	12/10/2021	
Barcode Sample Number	00153908	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

15

Nameplate Data				Equipment Information		
Serial Number	86JF692104	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	75	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	12/10/2021	11/17/2021
Barcode Sample Number	00153907	00153864
PCB (D4059) ppm	< 1	74.1
Oil Quality	Fluid test has No PCB.	Recommend disposing of PCB Contaminated fluid and or retrofilling equipment.

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

16

Nameplate Data				Equipment Information		
Serial Number	841096851	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	12/10/2021	
Barcode Sample Number	00153891	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

17

Nameplate Data				Equipment Information		
Serial Number	92LN128010	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	100	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	12/10/2021	
Barcode Sample Number	00153892	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#633



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

18

Nameplate Data				Equipment Information		
Serial Number	941057483	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/18/2022
Barcode Sample Number	00166931
PCB (D4059)	ppm < 1

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

19

Nameplate Data				Equipment Information		
Serial Number	20107297241	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	100	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	12/10/2021	
Barcode Sample Number	00153906	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

20

Nameplate Data				Equipment Information		
Serial Number	3737845194	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160817	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

21

Nameplate Data				Equipment Information		
Serial Number	1666231294	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	75	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00153919	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

22

Nameplate Data				Equipment Information		
Serial Number	73L621081	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	25	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	02/11/2022	
Barcode Sample Number	00166916	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

23

Nameplate Data				Equipment Information		
Serial Number	2001291-03	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160810	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

24

Nameplate Data				Equipment Information		
Serial Number	901024471	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/18/2022
Barcode Sample Number	00166921
PCB (D4059) ppm	< 1

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

25

Nameplate Data				Equipment Information		
Serial Number	941133330	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	25	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022
Barcode Sample Number	00160814
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

26

Nameplate Data				Equipment Information		
Serial Number	73L622040	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	25	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/18/2022
Barcode Sample Number	00166934
PCB (D4059) ppm	< 1

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

27

Nameplate Data				Equipment Information	
Serial Number	1065170295	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date		03/30/2022
Barcode Sample Number	00166949	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

28

Nameplate Data				Equipment Information		
Serial Number	1257180594	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	75	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date		03/30/2022
Barcode Sample Number		00166953
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

29

Nameplate Data				Equipment Information		
Serial Number	941016389	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	25	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160819	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

30

Nameplate Data				Equipment Information		
Serial Number	941016373	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	25	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160813	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

31

Nameplate Data				Equipment Information		
Serial Number	1257210594	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	75	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/30/2022	
Barcode Sample Number	00166950	
PCB (D4059) ppm	< 1	
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

32

Nameplate Data				Equipment Information		
Serial Number	N468952YEUA	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	100	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/18/2022	
Barcode Sample Number	00166920	
PCB (D4059)	ppm	< 1

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

33

Nameplate Data				Equipment Information		
Serial Number	901024443	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160832	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

34

Nameplate Data				Equipment Information		
Serial Number	931050309	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160834	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

35

Nameplate Data				Equipment Information		
Serial Number	60808724917	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/30/2022	
Barcode Sample Number	00166955	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

36

Nameplate Data				Equipment Information		
Serial Number	931119827	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00160811	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

37

Nameplate Data				Equipment Information		
Serial Number	74H803072	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date		03/30/2022
Barcode Sample Number	00166954	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

38

Nameplate Data				Equipment Information		
Serial Number	901027038	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	03/18/2022
Barcode Sample Number	00166924
PCB (D4059) ppm	< 1

635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

39

Nameplate Data				Equipment Information		
Serial Number	18A5275807	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)	
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition	
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed	
Gallons		KVA Rating	50	Leaks	Radiators	
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments	
Substation Location	Apparatus	Breathing Configuration				

Sample Date	01/07/2022	
Barcode Sample Number	00153922	
PCB (D4059) ppm	< 1	
Oil Quality	Fluid test has No PCB.	

#635



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

40

Nameplate Data			
Serial Number	941133310	Unit ID	PAD
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	01/07/2022
Barcode Sample Number	00160823
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.