



WADE R. FOWLER, JR., COMMISSIONER
EVELYN O. SHAW, COMMISSIONER
RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
MARION J NOLAND, INTERIM CEO/GENERAL MANAGER

FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

September 13, 2022

TO: All Prospective Bidders

FROM: Trent Ensley, Procurement Manager

SUBJECT: ADDENDUM NO. 3
PWC2223002 – 67,000v WYE with High Voltage LTC to 13,800V
DELTA FULL LOAD CONTINUOUSLY AT 37.34 MVA AT 65 C
GENERATOR STEUP TRANSFORMER (GSU)

1. The Specifications and Bid Documents are hereby modified or clarified per the attached documents.
 - a) Bidders are informed that the original “Ask Questions” date is hereby extended with a due date of September 27, 2022, no later than 5:00 p. m.
 - b) Delete all instances of the requirement for radiators in the transformer. The need to replace the radiators is due to space limitations at the Butler Warner Generation Plant. Add the requirement for coolers as a replacement for radiators. Please use the attached specification for coolers.
 - c) The following clarification is made to the specification. The available voltage is 480 V, 3-phase – 3W Delta for running all equipment. The available DC is 125 V DC. In the present specification it states 120/240 V AC is available, but this is not available.
 - d) The following clarification is provided to the bid documents. There is a (Load Tap Changer) LTC on the high voltage side and not the low voltage side of the transformer. With this addendum all references are deleted to “NO LTC”.

2. The foregoing changes or clarifications shall be incorporated in the original Bid Documents and a signed copy of this Addendum No. 3 shall accompany the bid to acknowledge the bidder’s receipt and familiarity with the changes and/or clarifications.

BUILDING COMMUNITY CONNECTIONS SINCE 1905

AN EQUAL EMPLOYMENT OPPORTUNITY EMPLOYER

TE: tke

Acknowledgement:

Company_____

By_____

Date_____