



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2223049

Bid Title : WATER TREATMENT AND WATER RECLAMATION CHEMICALS
ANNUAL CONTRACT

Bid Opening Date and Time: June 22, 2023, at 2:00 p.m.

Addendum Number: 2

Addendum Date: June 13, 2023

Procurement Advisor: *Tanya Hazlett*

Tanya.hazlett@faypwc.com | 910-223-4023

-
1. This addendum does not need to be returned.
 2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1. Question: Under the specifications for Sodium Hypochlorite page 10 number 3 states the specifications list 12% Chlorine, however, page 10 number 5 states required is 15% available Chlorine. Which one is correct?
A1: It should be 15% available chlorine delivered.
-

Check ONE of the following options:

- Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- Bid has been mailed. No changes resulted from this addendum.
- Bid has been mailed. Changes resulting from this addendum are as follows: