



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

**Bid Addendum**

**PWC Number:** PWC2223058

**Bid Title :** Big Rockfish Creek Outfall Contract II

**Bid Opening Date and Time:** July 25, 2023 @ 11:00 am

**Addendum Number:** 2

**Addendum Date:** July 13, 2023

**Procurement Advisor:** Tanya Hazlett  
Tanya.hazlett@faypwc.com



1. The solicitation is hereby modified as follows:

*M1. The Bid opening date will be extended from July 18, 2023, at 2:00 pm to July 25, 2023 @ 11:00 am. The location and conference room are unchanged from the original bid documents.*

2. Following are questions received about the solicitation and the SME's answers to the questions.

Q1. What internal restraint system for C900 was acceptable?

*A1: Specification Section 01000, add additional condition or provision under item 85, page 01000-42: "G. Acceptable internal restraint systems for C900 PVC pipe include the use of RieberLock and Diamond Lok-21 gaskets."*

3. Clarification: Pursuant to the mandatory Pre-bid meeting attendance requirement as set forth in the invitation to Bids and Special Provision-performance and Delivery, eligible prime bidders include:

- 1) ES&J Enterprises, Inc.
- 2) Terrahawk, LLC
- 3) Park Construction of North Carolina, Inc.
- 4) Sanford Contractors Inc.
- 5) T.A. Loving Company

**Failure to acknowledge receipt of this addendum may result in rejection of the response.**

Check ONE of the following options:

- Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- Bid has been mailed. No changes resulted from this addendum.
- Bid has been mailed. Changes resulting from this addendum are as follows:

**Execute Addendum:**

**Offeror:** \_\_\_\_\_

**Authorized Signature:** \_\_\_\_\_

**Name and Titled (Typed):** \_\_\_\_\_

**Date:** \_\_\_\_\_