



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2324068

Bid Title : Water Treatment and Water Reclamation Chemicals Annual Contract

Bid Opening Date and Time: April 17, 2024, at 2:00 p.m.

Addendum Number: II

Addendum Date: April 5, 2024

Procurement Advisor: JoAnn Bowman, Procurement Advisor
procurement@faypwc.com

-
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
 2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1. Section H – Hydrated Lime, Page 20, #4 – What are the names & physical addresses of the treatment plants that may require lime?**
 - A1.** Glenville Lake WTF, 628 Filter Plant Drive, Fayetteville, NC 28301.
 - Q2. Are current deliveries of the hydrated lime still 16 to 18 tons per delivery?**
 - A2.** Yes
 - Q3. Attachment H – Fayetteville Public Works Commission's MWDBE Compliance Provisions Does the Attachment H, MWDBE, Affidavit A & B, pages 38- 47 pertain to delivering lime, or does it pertain to a construction project?**
 - A3.** Delivering Lime. Please contact the Economic Inclusion Office using the following information for more information. EIProgram@faypwc.com
 - Q4. Will the quality of the various magnesium hydroxide products submitted in the bid be considered since comparing unit costs alone will not accurately demonstrate the true costs (or cost savings) associated with differing magnesium hydroxide products?**
 - A4.** Yes, the quality (e.g. lbs. of alkalinity) will play a major role in the selection of the vendor.
 - Q5. Does Fayetteville have any plans to implement a performance guarantee?**
 - A5.** A performance guarantee hasn't typically been a spec requirement. . The mag hydroxide requirement is 55-62% which allows for a +/-5% variance from typical lbs. of alkalinity. That's an acceptable range of variance.
 - Q6. If we are not a MWDBE, nor are we using entities that are listed as MWDBE Businesses, do we need to fill out and sign the forms regarding that subject?**
 - A6.** Yes

Failure to acknowledge receipt of this addendum may result in rejection of the response.

Check ONE of the following options:

- Bid has not been submitted. Any changes resulting from this addendum are included in our bid response.
- Bid has been submitted. No changes resulted from this addendum.
- Bid has been submitted. Changes resulting from this addendum are as follows:

Execute Addendum:

Offeror: _____

Authorized Signature: _____

Name and Titled (Typed): _____

Date: _____