



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2425022

Bid Title : Inventory – 2025 Composite Transmission Pole Contract

Bid Opening Date and Time: Tuesday, September 17, 2024, 4:00 pm

Addendum Number: 1

Addendum Date: August 28, 2024

Procurement Advisor: Carla Wint

procurement@faypwc.com

-
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
 2. The solicitation is hereby modified as follows:
 - M1** Attachment B Bid Pricing Form. The quantity of stock number 1220582 has increased from a quantity of 0 to a quantity of 10. PWC currently does not have historical usage data for 80', S-05.7. However, the Engineering department anticipates a need for approximately 10 of these poles for upcoming projects.
 3. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** Are all these poles tangent Structures?
 - A1.** Some of the poles are tangent and some are angles.
 - Q2.** Will any need to be self-supporting? This will impact pole selection on our end.
 - A2.** The angle poles will be guyed.
 - Q3.** Are we providing wood-equivalent composite poles? If so, are we comparing it to a wood pole of grade B or grade C construction?
 - A3.** Compare to a grade C construction.
 - Q4.** If we are not providing wood-equivalent FRP poles, please provide the design criteria (Is there a deflection limit? Do these poles need to transfer 100% of the class load? Fayetteville's transmission/distribution pole standards and specifications will help).
 - A4.** Reference IFB PWC2425020 Inventory - 2025 Galvanized Steel Transmission Pole Contract for the PWC Steel Transmission Pole Specifications. <https://www.faypwc.com/bids/>
 - Q5.** Is a single-piece pole at 75, 80, and 85 feet acceptable? Our standard poles will ship as single-piece monopoles.
 - A5.** PWC Prefers maximum Pole Sections to be less than 50' long for transportation and inventory.

Failure to acknowledge receipt of this addendum may result in rejection of the response.

Check ONE of the following options:

- ☐ Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- ☐ Bid has been mailed. No changes resulted from this addendum.
- ☐ Bid has been mailed. Changes resulting from this addendum are as follows:

Execute Addendum:

Offeror:

Authorized Signature:

Name and Titled (Typed):

Date:

ADDENDUM 1 ATTACHMENT B: BID PRICING FORM (PWC2425022)

Bidder Information:

Name of Company

Address

Phone Number

Email Address

Federal ID No.

**Is the business SDBE,
MWBE, DBE, or HUB?**

Printed Name

Title

Signature

Date

Company Name: _____

Bidders shall submit bids only on the Bid Pricing Forms provided herein, or exact copies thereof. Failure to provide a full and complete Bid Pricing Form using the form provided herein will result in a bid being deemed non-responsive.

Furnish And Deliver:

Stock #	EST. ONE YEAR QTY.	UOM	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1220575	55	EA	POLE, COMPOSITE, 75 FT, S-04.2 Manufacturer: Lead Time:	\$	\$
1220580	35	EA	POLE, COMPOSITE, 80 FT, S-04.2 Manufacturer: Lead Time:	\$	\$
1220581	40	EA	POLE, COMPOSITE, 80 FT, S-04.9 Manufacturer: Lead Time:	\$	\$
1220582	10	EA	POLE, COMPOSITE, 80',S-05.7 Manufacturer: Lead Time:	\$	\$

Company Name: _____

1220585	5	EA	POLE, COMPOSITE, 85',S-04.9 Manufacturer: Lead Time:	\$	\$
1220586	2	EA	POLE, COMPOSITE, 85', S-05.7 Manufacturer: Lead Time:	\$	\$

TOTAL EXTENDED PRICE: \$ _____