

RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
CHRISTOPHER G. DAVIS, COMMISSIONER
RICHARD W. KING, COMMISSIONER
TIMOTHY L. BRYANT, CEO/GENERAL MANAGER



FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

February 13, 2025

To: Potential Surplus Transformer Bidders
From: Paula Eckard, Supply Chain Analyst
CC: Elbert Norris, Apparatus Repair Shop Supervisor
Subject: Bid No. PWC2425057 for Surplus Transformer Shipment #662 Overhead

Fayetteville Public Works Commission hereinafter referred to as Commission manages and controls various pieces of equipment. As the legal title holder of equipment, the Commission has approved the sale of equipment by sealed bid. The surplus transformer shipment #662 consists of one (1) lot of seventy-five (75) overhead transformers, totaling 2040 KVA.

The Commission will accept sealed bids for this equipment until 2:00 p.m., Thursday, February 27, 2025, at Fayetteville PWC, PO Box 1089, Fayetteville, NC 28301 or 1097 Public Works Drive, Fayetteville, NC 23301 Attn: Paula Eckard. All bids received shall be opened in public and the amount of each bid announced and recorded.

In order for a bid to be considered, the bidder must be pre-qualified to dispose of transformers. Bidding information may be viewed online at <https://www.faypwc.com/bids/>

The Commission reserves the right to withdraw the equipment from sale at any time and the right to reject any and all bids, waive all informalities concerning a bid or award a bid to the highest responsible bidder.

The successful bidder must remit payment within 30 calendar days from the bid award. The PWC Supply Chain Department accepts wire transfers, certified checks, or money orders as forms of payment. All items must be picked up from the PWC within 10 business days after receipt of payment. The PWC does provide loading, packing, shipping, and/or labor assistance for pickups. The successful bidder must arrange and perform all necessary transportation to ship, and/or remove the items. Property may be removed between the hours of 9:00 a.m. to 12:00 p.m. or 1:00 p.m. to 4:00 p.m. Monday through Friday, excluding State holidays.

Inquiries concerning the bidding process may be made to paula.eckard@faypwc.com, if you have prequalification or technical questions about the units offered, please contact elbert.norris@faypwc.com.

BUILDING COMMUNITY CONNECTIONS SINCE 1905

AN EQUAL EMPLOYMENT OPPORTUNITY EMPLOYER

5 Kva total=	0	1-295-090	0	N G	Total Bad Units 69	Total Bad Units 6	Total Operational Units 69	Total = 75
6 Kva total=	18	1-295-100	0					
10 Kva total=	150	1-295-106	0					
15 Kva total=	0	1-295-108	0					
25 Kva total=	676	1-295-115	0					
37.5 Kva total=	0	1-295-166	0	Mfg Totals	AC	4		
60 Kva total=	350	1-295-205	0		ABB	6		
75 Kva total=	0	1-295-220	1		C.E.	0		
100 Kva total=	100	1-295-315	2		C.M.	0		
250 Kva total=	0	1-295-321	1		COOPER	10		
Total KVA	2948.0	1-295-330	4		ERMCO	27		
		1-295-331	11		GE	8		
		1-295-340	2		HOWARD	2		
		1-295-350	8		KUHLMAN	1		
		1-295-365	0		MCORAW EDISON	0		
Total 5 Kva =	0	1-295-369	6	RTG	7			
Total 6 Kva =	18	1-295-370	21	WEST	12			
Total 10 Kva =	150	1-295-375	0	PAUW	1			
Total 15 Kva =	0	1-295-395	0	Total	75			
Total 25 Kva =	676	1-295-205	2					
Total 37.5 Kva =	0	1-295-400	12					
Total 60 Kva =	350	1-295-840	1					
Total 75 Kva =	0	0	0					
Total 100 Kva =	100	0	0					
Total 250 Kva =	0	0	0					
Total	75	Total Units	75					

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	95A102262	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218235	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	73J3209	Unit ID	URD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218232	
PCB (D4059)	ppm	11.8
Oil Quality	Fluid test as Non-PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	Q416494-YWJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218236	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

41

Nameplate Data				Equipment Information	
Serial Number	73J3207	Unit ID	URD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	12/03/2023	
Barcode Sample Number	00218233	
PCB (D4059)	ppm	11.7
Oil Quality	Fluid test as Non-PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

5

Nameplate Data				Equipment Information	
Serial Number	92A245432	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218226	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

6

Nameplate Data				Equipment Information	
Serial Number	90A393476	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218225	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

7

Nameplate Data				Equipment Information	
Serial Number	841080551	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	5	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218228	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	93NH345008	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	10
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date 12/08/2023

Barcode Sample Number 00218229

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

9

Nameplate Data				Equipment Information	
Serial Number	34570-1784	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	12/08/2023	
Barcode Sample Number	00218234	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

10

Nameplate Data				Equipment Information	
Serial Number	Q361713-YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
allons		KVA Rating		Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	11/01/2024
Barcode Sample Number	00252660
PCB (D4059)	ppm < 1

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	5042108	Unit ID	URD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218245	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

12

Nameplate Data				Equipment Information	
Serial Number	73H2444	Unit ID	URD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024				
Barcode Sample Number	00218246				
PCB (D4059)	ppm	6.3			
Oil Quality		Fluid test as Non-PCB.			

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

13

Nameplate Data				Equipment Information	
Serial Number	B649434	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	5	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024				
Barcode Sample Number	00218249				
PCB (D4059)	ppm	10.2			
Oil Quality	Fluid test as Non-PCB.				

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

14

Nameplate Data				Equipment Information	
Serial Number	17X3842723	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218251	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

15

Nameplate Data				Equipment Information	
Serial Number	Q664778-YPL	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218250	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

16

Nameplate Data				Equipment Information	
Serial Number	88A511919	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218252	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	88A511925	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	50
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date 02/09/2024

Barcode Sample Number 00218253

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	30U2819747	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date 02/09/2024

Barcode Sample Number 00218254

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

19

Nameplate Data				Equipment Information	
Serial Number	30U2819753	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024		
Barcode Sample Number	00218255		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

20

Nameplate Data				Equipment Information	
Serial Number	44U2902337	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218256	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

21

Nameplate Data				Equipment Information	
Serial Number	30U2819758	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218258	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

22

Nameplate Data				Equipment Information	
Serial Number	91NN605020	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218261	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

23

Nameplate Data				Equipment Information	
Serial Number	38X3987517	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		02/09/2024
Barcode Sample Number		00218259
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

24

Nameplate Data				Equipment Information	
Serial Number	30U2819783	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218260	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Q5

Nameplate Data				Equipment Information	
Serial Number	Q416440-YWJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252457	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	72C4748	Unit ID	URD
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	50
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date 02/09/2024

Barcode Sample Number 00252453

PCB (D4059) ppm 24.6

Oil Quality Fluid test as Non-PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

27

Nameplate Data				Equipment Information	
Serial Number	891137166	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252456	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	30Y4383202	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date 02/09/2024

Barcode Sample Number 00252440

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

29

Nameplate Data				Equipment Information	
Serial Number	30U2819649	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00218262	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

30

Nameplate Data				Equipment Information	
Serial Number	50025-2486	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252441	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	29Y4383160	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date 02/09/2024

Barcode Sample Number 00252443

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

32

Nameplate Data				Equipment Information	
Serial Number	A0007265690	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	02/09/2024		
Barcode Sample Number	00252442		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

33

Nameplate Data				Equipment Information	
Serial Number	89NN108-025	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date		02/09/2024
Barcode Sample Number		00252444
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

34

Nameplate Data				Equipment Information	
Serial Number	30U2819782	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252445	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

35

Nameplate Data				Equipment Information	
Serial Number	91NN605011	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252446	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

36

Nameplate Data				Equipment Information	
Serial Number	91NN605019	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		02/09/2024
Barcode Sample Number		00252448
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number 38X3987524 Unit ID OH
Equipment Type Transformer Manufacturer
Year Manufactured Primary KV
Gallons KVA Rating 10
Phases 1 Fluid type Mineral Oil
Substation Breathing
Location Apparatus Configuration

Equipment Information

Top Valve (in) Bottom Valve (in)
Hose Length (ft) Paint Condition
Conservator Tank Bushings Enclosed
Leaks Radiators
Service Energized Compartments

Sample Date 02/09/2024

Barcode Sample Number 00252447

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

38

Nameplate Data				Equipment Information	
Serial Number	17X3842890	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252449	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

39

Nameplate Data				Equipment Information	
Serial Number	72L3148	Unit ID	URD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	100	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	02/09/2024	
Barcode Sample Number	00252451	
PCB (D4059)	ppm	13.5
Oil Quality	Fluid test as Non-PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

40

Nameplate Data				Equipment Information	
Serial Number	66AG5977	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		02/09/2024	
Barcode Sample Number		00252452	
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

41

Nameplate Data				Equipment Information	
Serial Number	4918384	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252481	
PCB (D4059)	ppm	9.6
Oil Quality	Fluid test as Non-PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

CP

Nameplate Data				Equipment Information	
Serial Number	4013140884	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252483	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#663



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

LB

Nameplate Data				Equipment Information	
Serial Number	871114948	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252482		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

614

Nameplate Data				Equipment Information	
Serial Number	4923195	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252484	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

45

Nameplate Data				Equipment Information	
Serial Number	30U2819760	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252485	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

46

Nameplate Data				Equipment Information	
Serial Number	01W3329106	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date		03/15/2024
Barcode Sample Number		00252486
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

47

Nameplate Data				Equipment Information	
Serial Number	91NE204012	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252487		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

48

Nameplate Data				Equipment Information	
Serial Number	95A102285	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252488		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

49

Nameplate Data				Equipment Information	
Serial Number	84A041807	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252489		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	97NH483067	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252490	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

51

Nameplate Data				Equipment Information	
Serial Number	881102491	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252496		
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

52

Nameplate Data				Equipment Information	
Serial Number	93NB101035	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252495		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

53

Nameplate Data				Equipment Information	
Serial Number	72AJ10601	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252497	
PCB (D4059)	ppm	3.2
Oil Quality	Fluid test as Non-PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

54

Nameplate Data				Equipment Information	
Serial Number	90A393457	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252498	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

55

Nameplate Data				Equipment Information	
Serial Number	89A073101	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252499	
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

56

Nameplate Data				Equipment Information	
Serial Number	94A064660	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252500		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

57

Nameplate Data				Equipment Information	
Serial Number	35A5419425	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 03/22/2024					
Barcode Sample Number 00252522					
PCB (D4059)	ppm	< 1			
Oil Quality		Fluid test has No PCB.			

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

58

Nameplate Data				Equipment Information	
Serial Number	40K1238104	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 03/22/2024					
Barcode Sample Number 00252521					
PCB (D4059)	ppm	< 1			
Oil Quality		Fluid test has No PCB.			

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

59

Nameplate Data				Equipment Information	
Serial Number	3228874	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/22/2024		
Barcode Sample Number	00252524		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

60

Nameplate Data				Equipment Information	
Serial Number	40K1238116	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/22/2024	
Barcode Sample Number	00252523	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

61

Nameplate Data				Equipment Information	
Serial Number	30U2819729	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252503	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

62

Nameplate Data				Equipment Information	
Serial Number	93NJ373132	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	03/15/2024		
Barcode Sample Number	00252502		
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

63

Nameplate Data				Equipment Information	
Serial Number	30U2819602	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252504	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#66d



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

661

Nameplate Data				Equipment Information	
Serial Number	44U2902349	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252492	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

65

Nameplate Data				Equipment Information	
Serial Number	30U2819628	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252493	
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

66

Nameplate Data				Equipment Information	
Serial Number	17A5257412	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date	03/15/2024				
Barcode Sample Number	00252494				
PCB (D4059)	ppm	< 1			
Oil Quality		Fluid test has No PCB.			

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

67

Nameplate Data				Equipment Information	
Serial Number	30U2819651	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/15/2024	
Barcode Sample Number	00252491	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

68

Nameplate Data				Equipment Information	
Serial Number	891048405	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	05/10/2024	
Barcode Sample Number	00252530	
PCB (D4059)	ppm	< 1

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

69

Nameplate Data				Equipment Information	
Serial Number	891048399	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 05/10/2024					
Barcode Sample Number 00252529					
PCB (D4059) ppm < 1					

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

70

Nameplate Data				Equipment Information	
Serial Number	91NN719013	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 05/10/2024					
Barcode Sample Number 00252531					
PCB (D4059) ppm < 1					

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	90207552398	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	05/10/2024
Barcode Sample Number	00252537
PCB (D4059)	ppm < 1

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	69AM11911	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	05/10/2024	
Barcode Sample Number	00252526	
PCB (D4059)	ppm	2.3
Oil Quality	Fluid test as Non-PCB.	

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

73

Nameplate Data				Equipment Information	
Serial Number	13T2405238	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	05/10/2024
Barcode Sample Number	00252547
PCB (D4059)	ppm < 1

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

74

Nameplate Data				Equipment Information	
Serial Number	881130695	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	5	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			
Sample Date	05/10/2024				
Barcode Sample Number	00252548				
PCB (D4059)	ppm	< 1			

#662



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

75

Nameplate Data				Equipment Information	
Serial Number	95NC285014	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 05/10/2024					
Barcode Sample Number 00252546					
PCB (D4059) ppm < 1					



PWC2425057 Surplus Transformer Shipment Lot #662,

Due February 27, 2025

Bid Pricing Form

Bidders Information

Bidders Name: _____

Street Address: _____

Telephone Number: _____

Email: _____

Print Name and Title: _____

Bidders Authorized Signature: _____

Date: _____

Pricing

LOT	QTY (LOT KVA TOTAL)	UNIT COST	EXTENDED COST
662	2040		