



**FAYETTEVILLE PUBLIC WORKS COMMISSION**

**PROCUREMENT DEPARTMENT**

<https://www.faypwc.com/bids/>

**Bid Addendum**

**PWC Number:** PWC2425060

**Bid Title:** RESIDENTIAL BACKFLOW PREVENTIONS ASSEMBLY TESTING

**Bid Opening Date and Time:** Thursday, March 20, 2025, 4:00 p.m.

**Addendum Number:** 1

**Addendum Date:** Thursday, March 13, 2025

**Procurement Advisor:** Leticia B. Gilmore  
[procurement@faypwc.com](mailto:procurement@faypwc.com)

- 
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
  2. Following are questions received about the solicitation and the SME's answers to the questions.
    - Q1.** Is a plumber license required to bid?
    - A1.** A plumber license is not required to bid. Eligible Bidders must have employee(s) that is/are a "Certified Backflow Prevention Assembly Tester" with a current/active backflow device test certificate from a PWC approved backflow testing certification school at the time of bid submission. Reference Scope of Work – Section I – General, paragraph 4.
- 

**Failure to acknowledge receipt of this addendum may result in rejection of the response.**

Check ONE of the following options:

- ☐ Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- ☐ Bid has been mailed. No changes resulted from this addendum.
- ☐ Bid has been mailed. Changes resulting from this addendum are as follows:

**Execute Addendum:**

**Offeror:** \_\_\_\_\_

**Authorized Signature:** \_\_\_\_\_

**Name and Titled (Typed):** \_\_\_\_\_

**Date:** \_\_\_\_\_