

RONNA ROWE GARRETT, COMMISSIONER  
DONALD L. PORTER, COMMISSIONER  
CHRISTOPHER G. DAVIS, COMMISSIONER  
RICHARD W. KING, COMMISSIONER  
TIMOTHY L. BRYANT, CEO/GENERAL MANAGER



FAYETTEVILLE PUBLIC WORKS COMMISSION  
955 OLD WILMINGTON RD  
P.O. BOX 1089  
FAYETTEVILLE, NORTH CAROLINA 28302-1089  
TELEPHONE (910) 483-1401  
WWW.FAYPWC.COM

August 28, 2025

To: Potential Surplus Transformer Bidders  
From: Paula Eckard, Supply Chain Analyst  
CC: Elbert Norris, Apparatus Repair Shop Supervisor  
Subject: Bid No. PWC2526013 for Surplus Transformer Shipment #670 Overhead

Fayetteville Public Works Commission hereinafter referred to as Commission manages and controls various pieces of equipment. As the legal title holder of equipment, the Commission has approved the sale of equipment by sealed bid. The surplus transformer shipment #670 consists of one (1) lot of seventy-five (75) Overhead, totaling 2102 KVA.

The Commission will accept sealed bids for this equipment until 2:00 p.m., Thursday, September 11, 2025, at Fayetteville PWC, PO Box 1089, Fayetteville, NC 28301 or 1097 Public Works Drive, Fayetteville, NC 28301 Attn: Paula Eckard. All bids received shall be opened in public and the amount of each bid announced and recorded.

In order for a bid to be considered, the bidder must be pre-qualified to dispose of transformers. Bidding information may be viewed online at <https://www.faypwc.com/bids/>

The Commission reserves the right to withdraw the equipment from sale at any time and the right to reject any and all bids, waive all informalities concerning a bid or award a bid to the highest responsible bidder.

The successful bidder must remit payment within 30 calendar days from the bid award. The PWC Supply Chain Department accepts wire transfers, certified checks, or money orders as forms of payment. Coordination for pick-up will be made with Paula Eckard, all items must be picked up from the PWC complex within 10 business days after receipt of payment. The PWC does provide loading, packing, shipping, and/or labor assistance for pickups. The successful bidder must arrange and perform all necessary transportation to ship, and/or remove the items. Property may be removed between the hours of 9:00 a.m. to 12:00 p.m. or 1:00 p.m. to 3:00 p.m. Monday through Friday, excluding State holidays.

Inquiries concerning the bidding process may be made to [paula.eckard@faypwc.com](mailto:paula.eckard@faypwc.com), if you have prequalification or technical questions about the units offered, please contact [elbert.norris@faypwc.com](mailto:elbert.norris@faypwc.com).

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	Weight	Work order	PPM	Manu.	Date O.S.	Co #	Y/MFG	2025
1	68AH9330	50	1-295-395	7200	120/240	G	CSP	640	2507721-02	<1.0	WH	5/8/25	012260	1968	57
2	A0608355412	25	1-295-365	7200	120/240	G	CSP	486	2405218-02	<1.0	ER	12/3/24	043026	2006	19
3	74AB6655	15	1-295-355	14400	120/240	G	CSP	300	2507100-01	<1.0	WH	3/18/25	020619	1974	51
4	38X3987551	10	1-295-331	7.2x14.4	120/240	G	CSP	300	2504022-02	<1.0	ER	3/11/25	031917	1994	31
5	89A071366	50	1-295-400	7.2x14.4	120/240	G	CSP	730	2506796-02	<1.0	WH	3/19/25	026236	1989	36
6	92A245381	25	1-295-370	7.2x14.4	120/240	G	CSP	500	2507244-01	<1.0	AB	3/22/25	028862	1992	33
7	3395244494	10	1-295-331	7.2x14.4	120/240	G	CSP	311	2504022-02	<1.0	HI	2/4/25	032227	1994	31
8	87NG242-045	50	1-295-400	7.2x14.4	120/240	G	CSP	693	2506410-01	<1.0	ME	2/14/25	025136	1987	38
9	IZ11161	15	1-295-350	7.2x14.4	120/240	G	CSP	264	2500767-02	<1.0	ME	8/28/24	027292	1992	33
10	Q416543-YWJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2504022-02	<1.0	GE	2/5/25	032175	1994	31
11	30608216786	25	1-295-365	7200	120/240	G	CSP	488	2505238-01	<1.0	ER	12/22/24	042552	2006	19
12	90007249157	25	1-295-365	7200	120/240	G	CSP	420	2502601-02	<1.0	ER	11/4/24	037148	2000	25
13	81009077519	50	1-295-395	7200	120/240	G	CSP	616	2506708-01	<1.0	ER	2/25/25	047491	2010	15
14	11911295738	50	1-295-395	7200	120/240	G	CSP	605	2504992-01	<1.0	ER	12/9/24	052711	2019	6
15	07W3377113	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2506898-02	<1.0	ER	3/11/25	029630	1990	35
16	7241-0390	75	1-295-416	7.2x14.4	120/240	G	CSP	1082	2506786-02	<1.0	HI	3/6/25	026950	1990	35
17	73L13475	50	1-295-395	7200	120/240	G	CSP	6780	2506928-01	<1.0	WH	3/7/25	011549	1973	52
18	94NA263058	10	1-295-331	7.2x14.4	120/240	G	CSP	656	2412952-07	<1.0	CP	10/30/24	031031	1996	29
19	92A123708	25	1-295-370	7.2x14.4	120/240	G	CSP	480	2504084-02	<1.0	AB	3/12/25	028547	1992	33
20	76A183961	50	1-295-395	7200	120/240	G	CSP	546	2506468-01	<1.0	WH	3/11/25	010845	1976	49
21	40B6018912	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2506796-02	<1.0	ER	3/19/25	035667	1998	27
22	38M1414256	25	1-295-365	7200	120/240	G	CSP	435	2507069-02	<1.0	ER	3/19/25	023534	1991	34
23	901004472	10	1-295-331	7.2x14.4	120/240	G	CSP	300	2504022-02	<1.0	RT	3/19/25	026930	1990	35
24	38X3987528	10	1-295-331	7.2x14.4	120/240	G	CSP	300	2504022-02	<1.0	ER	3/24/25	031985	1994	31
25	07W3377111	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2502494-02	<1.0	ER	7/20/24	029607	1993	32
26	901122607	15	1-295-350	7.2x14.4	120/240	G	CSP	245	2501858-02	<1.0	CP	9/5/24	027457	1990	35
27	IZ11256	15	1-295-350	7.2x14.4	120/240	G	CSP	264	2501998-02	<1.0	ME	9/5/24	027293	1960	65
28	30U2819631	15	1-295-350	7.2x14.4	120/240	G	CSP	305	2412168-02	<1.0	ER	7/29/24	027913	1991	34
29	00A113584	25	1-295-365	7200	120/240	G	CSP	342	2504054-02	<1.0	AB	10/29/24	037948	2000	25
30	00A113575	25	1-295-365	7200	120/240	G	CSP	342	2504153-02	<1.0	AB	10/30/24	037930	2000	25
31	76A183969	50	1-295-395	7200	120/240	G	CSP	646	2506457-01	<1.0	WH	2/16/25	0201AD	1976	49
32	09V3009912	50	1-295-400	7.2x14.4	120/240	G	CSP	655	2506261-02	<1.0	ER	2/27/25	028523	1992	33
33	871057560	15	1-295-350	7.2x14.4	120/240	G	CSP	325	2506358-02	<1.0	RT	2/26/25	024473	1987	38
34	Q416517-WYJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2504022-02	<1.0	GE	2/25/25	032141	1994	31
35	187507404	167	1-295-141	7.2x14.4	120/240	G	Conv.	1488	2506796-02	<1.0	CM	3/19/25	025183	1987	38
36	Q416454-YWJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2507542-01	<1.0	GE	3/31/25	032051	1994	31
37	Q416483-YWJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2507138-02	<1.0	GE	4/1/25	032101	1994	31
38	35A5419459	25	1-295-370	7.2x14.4	120/240	G	CSP	410	2507138-02	<1.0	ER	4/15/25	034485	1997	28
39	Q416551-YWJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2507138-02	<1.0	GE	4/11/25	032128	1994	31
40	93NK409021	10	1-295-331	7.2x14.4	120/240	G	CSP	288	2507138-02	<1.0	CP	4/4/25	030384	1993	32
41	90608333725	50	1-295-395	7200	120/240	N	CSP	663	2507655-01	<1.0	ER	4/8/25	042872	2006	19
42	66AK9181	50	1-295-395	7200	120/240	G	CSP	685	2507640-02	<1.0	WH	4/14/25	054071	1966	59
43	71409912306	25	1-295-365	7200	120/240	G	CSP	371	2504966-01	<1.0	ER	12/5/24	049572	2014	11
44	90608333721	50	1-295-395	7200	120/240	G	CSP	663	2400387-01	<1.0	ER	7/10/23	042868	2006	19
45	51J1055709	15	1-295-340	7200	120/240	G	CSP	320	2507138-02	<1.0	ER	4/23/25	022033	1992	33
46	91109288659	25	1-295-365	7200	120/240	G	CSP	369	2504994-01	<1.0	ER	12/8/24	048266	2011	14
47	93NJ373112	25	1-295-370	7.2x14.4	120/240	G	CSP	466	2506044-02	<1.0	CP	4/2/25	030305	1993	32
48	891137157	25	1-295-370	7.2x14.4	120/240	G	CSP	435	2500502-02	<1.0	RT	12/4/24	026744	1989	36
49	66AG2182	50	1-295-395	7200	120/240	G	CSP	685	2503289-02	<1.0	WH	12/10/24	054068	1966	59
50	Q416464-YWJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2500502-02	<1.0	GE	12/3/24	032149	1994	31
51	871107071	15	1-295-350	7.2x14.4	120/240	G	CSP	325	2500502-02	<1.0	RT	12/4/24	024865	1987	38
52	34602-1784	15	1-295-340	7200	120/240	G	CSP	340	2502854-01	<1.0	HI	9/8/24	022453	1984	41
53	89907045452	10	1-295-330	7200	120/240	G	CSP	239	2405215-02	<1.0	ER	2/22/24	036377	1999	26
54	91NN605016	15	1-295-350	7.2x14.4	120/240	G	CSP	318	2506126-02	<1.0	CP	2/3/25	028412	1991	34
55	Q361871-YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2506277-02	<1.0	GE	5/5/25	032166	1994	31
56	40B6018955	10	1-295-331	7.2x14.4	120/240	G	CSP	220	2502002-02	<1.0	ER	4/6/24	035692	1998	27
57	92012014681	10	1-295-330	7200	120/240	G	CSP	240	FROM YARD	<1.0	ER	4/2/25	052232	2020	5
58	27B5921827	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2506044-02	<1.0	ER	4/3/25	035450	1998	27
59	*0099679	25	1-295-365	7200	120/240	G	CSP	489	2410214-02	<1.0	ER	4/9/24	040657	2004	21

No Oil

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	Weight	Work order	PPM	Manu.	Date O.S.	Co #	Y/MFG	2025	
60	06W3353156	25	1-295-370	7.2x14.4	120/240	G	CSP	390	2507138-02	<1.0	ER	4/4/25	029516	1993	32	No Oil
61	36V3204011	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2506044-02	<1.0	ER	4/13/25	029106	1992	33	NO OIL
62	71AH2397	25	1-295-365	7200	120/240	G	CSP	410	2507138-02	<1.0	WH	4/16/25	009756	1971	54	NO OIL
63	891049966	10	1-295-331	7.2x14.4	120/240	G	CSP	300	2503061-02	<1.0	RT	11/21/24	026473	1989	36	
64	06W3353128	25	1-295-370	7.2x14.4	120/240	G	CSP	390	2509202-02	<1.0	ER	12/30/24	029554	1994	31	
65	Q361750-YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	660	2500502-02	<1.0	GE	11/5/24	031491	1994	31	
66	93A482046	50	1-295-400	7.2x14.4	120/240	G	CSP	694	2504853-01	<1.0	CP	12/3/24	030628	1993	32	
67	13T2405200	15	1-295-350	7.2x14.4	120/240	G	CSP	310	2504022-02	<1.0	ER	2/25/25	027191	1992	33	
68	38X3987568	10	1-295-331	7.2x14.4	120/240	G	CSP	300	2506505-02	<1.0	ER	2/24/25	031915	1994	31	
69	05X3731702	50	1-295-400	7.2x14.4	120/240	G	CSP	660	2506400-02	<1.0	ER	2/23/25	030862	1994	31	
70	1412183990	10	1-295-331	7.2x14.4	120/240	G	CSP	311	2506249-02	<1.0	HI	2/26/25	027404	1990	35	
71	70AK9389	50	1-295-395	7200	120/240	G	CSP	649	2506719-02	1.3	WH	2/26/25	012254	1970	55	
72	30407796386	25	1-295-365	7200	120/240	G	CSP	489	2410214-02	<1.0	ER	4/9/24	040657	2004	21	NO OIL
73	90107397353	25	1-295-365	7200	120/240	G	CSP	373	2504432-02	<1.0	ER	11/18/24	038562	2001	24	
74	60307676229	25	1-295-365	7200	120/240	N	CSP	489	2506457-01	<1.0	ER	2/16/25	040208	2003	22	
75	10207441507	25	1-295-365	7200	120/240	N	CSP	415	2507613-01	<1.0	ER	4/5/25	039127	2002	23	

Total KVA = 2102.0

Total Lbs= 41243

AVG= 32  
 Total Units >= 30 years 52  
 Total Units >=20 and < = 30 23  
 Total Units < 20 9  
 Total = 75

5 Kva total=	0
10 Kva total=	170
15 Kva total=	165
25 Kva total=	725
50 Kva total=	800
75 Kva total=	75
167 Kva total=	167

Total KVA 2102.0

Total# 10 Kva =	17
Total# 15 Kva =	11
Total# 25 Kva =	29
Total# 50 Kva =	16
Total# 75 Kva =	1
Total# 167 Kva =	1

<b>Total</b>	<b>75</b>
--------------	-----------

1-295-066	0
1-295-141	1
1-295-205	0
1-295-220	0
1-295-315	0
1-295-330	2
1-295-331	15
1-295-340	2
1-295-350	8
1-295-365	14
1-295-370	15
1-295-375	0
1-295-395	11
1-295-400	5
1-295-355	1
1-295-416	1

Total# Units 75

N Total Bad Unit= 3  
 G Total Operational Units= 72  
 Total= 75

Mfg Totals  
 Central Moloney 1  
 ABB 4  
 COOPER 6  
 ERMCO 34  
 GE 8  
 HOWARD 4  
 McGraw Edison 3  
 RTE 5  
 WEST 10  
 PAUW 0

Total= 75

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	68AH9330	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 05/22/2025

Barcode Sample Number 00304873

PCB (D4059) ppm < 1  
Oil Quality Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

2

Nameplate Data				Equipment Information	
Serial Number	A060835412	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	05/22/2025
Barcode Sample Number	00304877

PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

3

**Nameplate Data**

Serial Number	74AB6655	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	15
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

**Equipment Information**

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

**Sample Date 04/03/2025**

Barcode Sample Number 00304755

PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

4

Nameplate Data				Equipment Information	
Serial Number	38X3987551	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304766	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

5

Nameplate Data				Equipment Information	
Serial Number	89A071366	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304754	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

6

Nameplate Data				Equipment Information	
Serial Number	92A245381	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304756	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

7

Nameplate Data				Equipment Information	
Serial Number	3395244494	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025
Barcode Sample Number	00304704

PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

8

Nameplate Data				Equipment Information	
Serial Number	87NG242-045	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025
Barcode Sample Number	00304706
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

**Nameplate Data**

Serial Number IZ11161 Unit ID OH  
Equipment Type Transformer Manufacturer  
Year Manufactured Primary KV  
Gallons KVA Rating 15  
Phases 1 Fluid type Mineral Oil  
Substation Breathing  
Location Apparatus Configuration

**Equipment Information**

Top Valve (in) Bottom Valve (in)  
Hose Length (ft) Paint Condition  
Conservator Tank Bushings Enclosed  
Leaks Radiators  
Service Energized Compartments

9

**Sample Date** 04/03/2025

**Barcode Sample Number** 00304806

**PCB (D4059)** ppm < 1

**Oil Quality** Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

10

Nameplate Data				Equipment Information	
Serial Number	Q416543-YWJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304702	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	30608216786	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304760	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

12

**Nameplate Data**

Serial Number	90007249157	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

**Equipment Information**

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

**Sample Date 04/03/2025**

Barcode Sample Number 00304763

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

13

**Nameplate Data** | **Equipment Information**

Serial Number	81009077519	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/03/2025

Barcode Sample Number 00304762

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

14

**Nameplate Data** | **Equipment Information**

Serial Number	11911295738	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/03/2025

Barcode Sample Number 00304761

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

15

Nameplate Data				Equipment Information	
Serial Number	07W3377113	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304738	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

16

Nameplate Data				Equipment Information	
Serial Number	7241-0390	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	75	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304736	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

17

Nameplate Data				Equipment Information	
Serial Number	73L13475	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304735	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

18

Nameplate Data				Equipment Information	
Serial Number	94NA263058	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304715	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

19

Nameplate Data			
Serial Number	92A123708	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	04/03/2025
Barcode Sample Number	00304767
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

#6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

20

**Nameplate Data** | **Equipment Information**

Serial Number	76A183961	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/03/2025

Barcode Sample Number 00304769

PCB (D4059) ppm < 1  
Oil Quality Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

21

Nameplate Data				Equipment Information	
Serial Number	40B6018912	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025
Barcode Sample Number	00304753
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

22

Nameplate Data				Equipment Information	
Serial Number	38M1414256	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304752	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

23

Nameplate Data			Equipment Information		
Serial Number	901004472	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025
Barcode Sample Number	00304764
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

24

Nameplate Data			Equipment Information		
Serial Number	38X3987528	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304765	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

25

Nameplate Data			Equipment Information		
Serial Number	07W3377111	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	02/17/2025
Barcode Sample Number	00304678	00252732
Specific Gravity (D1298/D4052)		0.0000
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

26

Nameplate Data				Equipment Information	
Serial Number	901122607	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304712	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

27

Nameplate Data				Equipment Information	
Serial Number	IZ11256	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304713	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

28

Nameplate Data				Equipment Information	
Serial Number	30U2819631	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	03/12/2025
Barcode Sample Number	00304714	00304711
PCB (D4059)	ppm < 1	< 1
Oil Quality	Fluid test has No PCB.	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

29

Nameplate Data				Equipment Information	
Serial Number	00A113584	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304709	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

30

Nameplate Data				Equipment Information	
Serial Number	00A113575	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304705	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

31

Nameplate Data				Equipment Information	
Serial Number	76A183969	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	03/12/2025
Barcode Sample Number	00304739	00304695
PCB (D4059)	ppm < 1	< 1
Oil Quality	Fluid test has No PCB.	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

32

Nameplate Data				Equipment Information	
Serial Number	09V3009912	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304696	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

33

Nameplate Data				Equipment Information	
Serial Number	871057560	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304698	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

34

Nameplate Data				Equipment Information	
Serial Number	Q416517-WYJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304697	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

35

Nameplate Data			Equipment Information		
Serial Number	187507404	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	167	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025
Barcode Sample Number	00304751
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

36

Nameplate Data			Equipment Information		
Serial Number	Q416454-YWJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025
Barcode Sample Number	00304807
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

37

Nameplate Data				Equipment Information	
Serial Number	Q416483-YWJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304808	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

38

**Nameplate Data** | **Equipment Information**

Serial Number	35A5419459	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/25/2025

Barcode Sample Number 00304825

PCB (D4059) ppm < 1  
Oil Quality Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

39

Nameplate Data				Equipment Information	
Serial Number	Q416551-YWJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025
Barcode Sample Number	00304818
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

40

Nameplate Data				Equipment Information	
Serial Number	93NK409021	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025	
Barcode Sample Number	00304814	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

41

Nameplate Data				Equipment Information	
Serial Number	90608333725	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025
Barcode Sample Number	00304817
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

42

Nameplate Data			
Serial Number	66AK9181	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	50
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information		
Top Valve (in)	Bottom Valve (in)	
Hose Length (ft)	Paint Condition	
Conservator Tank	Bushings Enclosed	
Leaks	Radiators	
Service Energized	Compartments	

Sample Date	04/25/2025	
Barcode Sample Number	00304827	
PCB (D4059) ppm	< 1	
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

43

**Nameplate Data** | **Equipment Information**

Serial Number	71409912306	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 03/12/2025

Barcode Sample Number 00304694

PCB (D4059) ppm < 1  
Oil Quality Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

44

Nameplate Data				Equipment Information	
Serial Number	90608333721	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025
Barcode Sample Number	00304693
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

45

**Nameplate Data** | **Equipment Information**

Serial Number	51J1055709	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/25/2025

Barcode Sample Number 00304835

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

46

Nameplate Data				Equipment Information	
Serial Number	91109288659	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304692	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

47

Nameplate Data				Equipment Information	
Serial Number	93NJ373112	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025
Barcode Sample Number	00304834
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

48

Nameplate Data				Equipment Information	
Serial Number	891137157	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304691	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

49

Nameplate Data			
Serial Number	66AG2182	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	50
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	03/12/2025
Barcode Sample Number	00304699
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

50

Nameplate Data			
Serial Number	Q416464-WYJ	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information			
Top Valve (in)		Bottom Valve (in)	
Hose Length (ft)		Paint Condition	
Conservator Tank		Bushings Enclosed	
Leaks		Radiators	
Service Energized		Compartments	

Sample Date	03/12/2025		
Barcode Sample Number	00304700		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

#6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

51

Nameplate Data				Equipment Information	
Serial Number	871107071	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304690	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

52

Nameplate Data			Equipment Information		
Serial Number	34602-1784	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304770	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

53

Nameplate Data			Equipment Information		
Serial Number	89907045452	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025
Barcode Sample Number	00304811
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

54

Nameplate Data			Equipment Information		
Serial Number	91NN605016	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304677	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

55

Nameplate Data			
Serial Number	Q361871-YRJ	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information		
Top Valve (in)	Bottom Valve (in)	
Hose Length (ft)	Paint Condition	
Conservator Tank	Bushings Enclosed	
Leaks	Radiators	
Service Energized	Compartments	

Sample Date	05/22/2025	
Barcode Sample Number	00304871	
PCB (D4059) ppm	< 1	
Oil Quality	Fluid test has No PCB.	

#6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

56

**Nameplate Data** | **Equipment Information**

Serial Number	40B6018955	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 03/12/2025

Barcode Sample Number 00304707

PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

57

**Nameplate Data** | **Equipment Information**

Serial Number	92012014681	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

<b>Sample Date</b>	<b>04/25/2025</b>	<b>04/03/2025</b>
Barcode Sample Number	00304819	00304812
PCB (D4059) ppm	< 1	< 1
Oil Quality	Fluid test has No PCB.	Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

58

Nameplate Data				Equipment Information	
Serial Number	27B5921827	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025	
Barcode Sample Number	00304832	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

59

**Nameplate Data** | **Equipment Information**

Serial Number	0099679	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/25/2025

Barcode Sample Number 00304816

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

60

Nameplate Data			
Serial Number	06W3353156	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	04/25/2025
Barcode Sample Number	00304815
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

61

Nameplate Data				Equipment Information	
Serial Number	36V3204011	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025	
Barcode Sample Number	00304833	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

62

Nameplate Data				Equipment Information	
Serial Number	71AH2397	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/25/2025
Barcode Sample Number	00304826
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

63

Nameplate Data				Equipment Information	
Serial Number	891049966	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025
Barcode Sample Number	00304689

PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

64

Nameplate Data				Equipment Information	
Serial Number	06W3353128	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304701	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

65

Nameplate Data				Equipment Information	
Serial Number	Q361750-YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025
Barcode Sample Number	00304688
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

66

Nameplate Data				Equipment Information	
Serial Number	93A482046	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304687	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 6700H



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

67

Nameplate Data				Equipment Information	
Serial Number	13T2405200	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025
Barcode Sample Number	00304719
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

68

Nameplate Data				Equipment Information	
Serial Number	38X3987568	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304718	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

69

Nameplate Data				Equipment Information	
Serial Number	05X3731702	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304720	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

70

Nameplate Data				Equipment Information	
Serial Number	1412183990	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	03/12/2025	
Barcode Sample Number	00304708	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

71

**Nameplate Data**

Serial Number	70AK9389	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	50
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

**Equipment Information**

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

**Sample Date** 03/12/2025

Barcode Sample Number 00304679

PCB (D4059) ppm 1.3

Oil Quality Fluid test as Non-PCB.

#67004



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

72

Nameplate Data			Equipment Information		
Serial Number	30407796386	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025	
Barcode Sample Number	00304758	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

73

**Nameplate Data**

Serial Number	90107397353	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

**Equipment Information**

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

**Sample Date** 04/03/2025

Barcode Sample Number 00304810

PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

74

Nameplate Data				Equipment Information	
Serial Number	60307676229	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	04/03/2025
Barcode Sample Number	00304772
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

# 670 OH



Fayetteville Public Works  
Commission (Apparatus)  
955 Old Wilmington Rd  
Fayetteville, NC, 28302-1089

75

**Nameplate Data** | **Equipment Information**

Serial Number	10207441507	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

**Sample Date** 04/25/2025

Barcode Sample Number 00304813

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.



**Surplus Transformer Shipment Lot 670**

**Due September 11, 2025**

**PWC2526013 Bid Pricing Form**

Bidders Information

Bidders Name: \_\_\_\_\_

Street Address: \_\_\_\_\_

Telephone Number: \_\_\_\_\_

Email: \_\_\_\_\_

Print Name and Title: \_\_\_\_\_

Bidders Authorized Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Pricing

<b>LOT</b>	<b>QTY</b> <i>(LOT KVA TOTAL)</i>	<b>UNIT COST</b>	<b>EXTENDED COST</b>
670	2102		