



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2526014

Bid Title: MODIFICATIONS AT WATER RESOURCES 7 BAY VEHICLE SHED

Bid Opening Date and Time: August 28, 2025, 2:00 p.m.

Addendum Number: 1

Addendum Date: Thursday, August 21, 2025

Procurement Advisor: JoAnn Bowman
joann.bowman@faypwc.com

-
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
 2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** The following question was submitted from a door manufacturer: "There is no way to fit doors on the existing openings. The columns are 10" wide and I need to have 9 3/4" on the drive side of the door and 6 3/4" on the spring adjuster side. Detail 11/S2.0 has block flush to the column all the way up with nothing to mount the guides to. If the doors are set up with opposing motors the spring adjuster ends could fit on column at line 5. Detail 9/S2.0 would not leave enough room for the drive side of the door. We would need both columns at lines 4 and 6 to be closed in by 10" minimum."
 - A1.** After discussions with the manufacturer that asked the question, the following is to be done to allow the doors to be installed: Provide an opening at the top of the new c.m.u. wall at column line 4 to provide room for the door drive motor (similar to how the original was installed at column line 6). The existing c.m.u. wall, shown in section 11/S2.0, is to be toothed out as required to allow the installation of the door guide rails by the door manufacturer. The new c.m.u. and mortar are to be colored to match the existing c.m.u. and mortar.
-

Failure to acknowledge receipt of this addendum may result in rejection of the response.

Check ONE of the following options:

- ☐ Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- ☐ Bid has been mailed. No changes resulted from this addendum.
- ☐ Bid has been mailed. Changes resulting from this addendum are as follows:

Execute Addendum:

Offeror:

Authorized Signature:

Name and Titled (Typed):

Date:
