



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2526030

Bid Title: Cable, 1/0 ALCN EPR 25KV, 1/C

Bid Opening Date and Time: October 7, 2025 @ 3:00 pm

Addendum Number: 1

Addendum Date: September 30, 2025

Procurement Advisor: *Leticia Gilmore*
procurement@faypwc.com

1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** Can we offer TRXLP as an alternate?
 - A1.** TRXLP is not an acceptable alternative.

Failure to acknowledge receipt of this addendum may result in rejection of the response

Check ONE of the following options:

- Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- Bid has been mailed. No changes resulted from this addendum.
- Bid has been mailed. Changes resulting from this addendum are as follows:

Execute Addendum:

Offeror: _____

Authorized Signature: _____

Name and Titled (Typed): _____

Date: _____