

RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
CHRISTOPHER G. DAVIS, COMMISSIONER
RICHARD W. KING, COMMISSIONER
TIMOTHY L. BRYANT, CEO/GENERAL MANAGER



FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

September 25, 2025

To: Potential Surplus Transformer Bidders
From: Paula Eckard, Supply Chain Analyst
CC: Elbert Norris, Apparatus Repair Shop Supervisor
Subject: Bid No. PWC2526039 for Surplus Transformer Shipment #688 Pad Mount

Fayetteville Public Works Commission hereinafter referred to as Commission manages and controls various pieces of equipment. As the legal title holder of equipment, the Commission has approved the sale of equipment by sealed bid. The surplus transformer shipment #688 consists of one (1) lot of four (4) Pad Mount, totaling 1400 KVA.

The Commission will accept sealed bids for this equipment until 2:30 p.m., Friday, October 12, 2025, at Fayetteville PWC, PO Box 1089, Fayetteville, NC 28301 or 1097 Public Works Drive, Fayetteville, NC 23301 Attn: Paula Eckard. All bids received shall be opened in public and the amount of each bid announced and recorded.

In order for a bid to be considered, the bidder must be pre-qualified to dispose of transformers. Bidding information may be viewed online at <https://www.faypwc.com/bids/>

The Commission reserves the right to withdraw the equipment from sale at any time and the right to reject any and all bids, waive all informalities concerning a bid or award a bid to the highest responsible bidder.

The successful bidder must remit payment within 30 calendar days from the bid award. The PWC Supply Chain Department accepts wire transfers, certified checks, or money orders as forms of payment. Coordination for pick-up will be made with Paula Eckard, all items must be picked up from the PWC complex within 10 business days after receipt of payment. The PWC does provide loading, packing, shipping, and/or labor assistance for pickups. The successful bidder must arrange and perform all necessary transportation to ship, and/or remove the items. Property may be removed between the hours of 9:00 a.m. to 12:00 p.m. or 1:00 p.m. to 3:00 p.m. Monday through Friday, excluding State holidays.

Inquiries concerning the bidding process may be made to paula.eckard@faypwc.com, if you have prequalification or technical questions about the units offered, please contact elbert.norris@faypwc.com.

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	Weight	Work order	PPM	Manu.	Date O.S.	Co #	YMFG	2025
1	846009875	300	1-295-705	7200	480Y/277	G	PAD	4150	2504143-02	<1.0	RT	10/3/24	023238	1984	41
2	1276973590	300	1-295-706	7.2x14.4	480Y/277	G	PAD	4309	2407620-02	<1.0	HI	1/7/24	027257	1990	35
3	866000965	300	1-295-710	14400	208Y/120	G	PAD	4150	2503864-02	<1.0	RT	10/19/24	023872	1986	39
4	73A395028	500	1-295-720	7200	208Y/120	G	PAD	4400	2410457-02	<1.0	WH	7/14/24	021259	1973	52
5															

Total KVA = 1400.0

Total Lbs= 17009

AVG= 42

Total Units >= 30 years 4

Total Units >=20 and < = 30 0

Total Units < 20 0

Total = 4

150 Kva total=	0
300 Kva total=	900
500 Kva total=	500
750 Kva total=	0
1000 Kva total=	0
1500 Kva total=	0

Total KVA 1400.0

Total# 150 Kva =	0
Total# 300 Kva =	3
Total# 500 Kva =	1
Total# 750 Kva =	0
Total# 1000 Kva =	0
Total# 1500 Kva =	0

Total	4
-------	---

1-295-665	0
1-295-670	0
1-295-675	0
1-295-677	0
1-295-700	0
1-295-701	0
1-295-705	1
1-295-706	1
1-295-710	1
1-295-720	1
1-295-732	0
1-295-741	0
1-295-747	0
1-295-755	0
1-295-770	0
1-295-775	0
1-295-780	0
1-295-785	0

Total# Units 4

N
G

Total Bad Unit= 0

Total Operational Units= 4

Total= 4

Mfg Totals

AC	0
ABB	0
C.E.	0
C.M.	0
COOPER	0
ERMCO	0
GE	0
HOWARD	1
KUHLMAN	0
MCGRW EDISON	0
RTE	2
WEST	1
PAUW	0
Total=	4

#688 3phase



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	846009875	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	RTE	Hose Length (ft)	Paint Condition
Year Manufactured	1984	Primary KV	7.2	Conservator Tank	Bushings Enclosed
Gallons	180	KVA Rating	300	Leaks	Radiators
Phases	3	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing	Sealed		
Location		Configuration			

Sample Date		04/25/2025
Barcode Sample Number		00304855
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

#689 3 phase



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	1276973590	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Howard	Hose Length (ft)	Paint Condition
Year Manufactured	1990	Primary KV	7.2	Conservator Tank	Bushings Enclosed
Gallons	192	KVA Rating	300	Leaks	Radiators
Phases	3	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing	Sealed		
Location		Configuration			

Sample Date	04/25/2025	
Barcode Sample Number	00304848	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#690 3phase



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	866000965	Unit ID	Pad	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	RTE	Hose Length (ft)	Paint Condition
Year Manufactured	1986	Primary KV	7.2 X 14.4	Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	300	Leaks	Radiators
Phases	3	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	11/14/2024
Barcode Sample Number	00252678
PCB (D4059)	ppm. < 1
Oil Quality	Fluid test has No PCB.

691 3 phase



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	73A395028	Unit ID	PAD	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Westinghouse	Hose Length (ft)	Paint Condition
Year Manufactured	1973	Primary KV	7.2	Conservator Tank	Bushings Enclosed
Gallons	300	KVA Rating	500	Leaks	Radiators
Phases	3	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration	Sealed		

Sample Date	04/25/2025	
Barcode Sample Number	00304853	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	



Surplus Transformer Shipment Lot 688

Due October 12, 2025

PWC2526039 Bid Pricing Form

Bidders Information

Bidders Name: _____

Street Address: _____

Telephone Number: _____

Email: _____

Print Name and Title: _____

Bidders Authorized Signature: _____

Date: _____

Pricing

LOT	QTY (LOT KVA TOTAL)	UNIT COST	EXTENDED COST
688	1400		