



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2526050

Bid Title: Cable, 1/0 ALCN EPR 25KV, 1/C

Bid Opening Date and Time: November 13, 2025 @ 2:00 pm

Addendum Number: 1

Addendum Date: November 4, 2025

Procurement Advisor: *Leticia Gilmore*
procurement@faypwc.com

1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** Will a thickness of minimum 45 mils, nominal 55 mils and maximum 70 mils be acceptable?
 - A1.** A minimum of 45 mils thickness is required for the outside diameter. All other dimensions should be within the tolerance of the specification to be accepted.

Failure to acknowledge receipt of this addendum may result in rejection of the response.

Check ONE of the following options:

- Bid has not been mailed. Any changes resulting from this addendum are included in our bid response.
- Bid has been mailed. No changes resulted from this addendum.
- Bid has been mailed. Changes resulting from this addendum are as follows:

Execute Addendum:

Offeror: _____

Authorized Signature: _____

Name and Titled (Typed): _____

Date: _____