



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2625049 Rebid

Bid Title: Switch, 69 KV 1200A, Unitized GOAB, Side Break Horizontal, 3-Way

Bid Opening Date and Time: March 10, 2026 @ 2:00 pm

Addendum Number: 1

Addendum Date: March 3, 2026

Procurement Advisor: *Lacoma Jones*
procurement@faypwc.com

1. Addenda acknowledgement is required within the IFB Bid Pricing Form.
2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** We are going to need to verify what type of operator PWC is wanting for this switch. The material specs for the bid request is a little unclear and calls for both of the following:
 - Control mechanism with pad-lockable operating handle assembly
 - Geared hand crank mechanism

I am going to guess they are looking for a pad-lockable, geared, handcrank operator for this quote – and not a swing handle, etc.

Please have PWC confirm exactly what is needed and I'll quote accordingly.

- A1.** The operator needs to be swing handles and not the gear crank.