



**FAYETTEVILLE PUBLIC WORKS COMMISSION**

**PROCUREMENT DEPARTMENT**

<https://www.faypwc.com/bids/>

**Bid Addendum**

**PWC Number:** PWC2625061

**Bid Title:** Inventory – 69KV Breakers

**Bid Opening Date and Time:** March 10, 2026 @ 3:00 pm

**Addendum Number:** 1

**Addendum Date:** March 3, 2026

**Procurement Manager:** *Nikole Bohannon*  
*procurement@faypwc.com*

1. Addenda acknowledgement is required within the IFB Bid Pricing Form.
  
2. Following are questions received about the solicitation and the SME's answers to the questions.
  - Q1.** I need I/O points they want included in optimizer.
  
  - A1.** Auxiliary points below:
    - Aux 1: Trip #1
    - Aux 2: Trip #2
    - Aux 3: Close
    - Aux 4: 52B
    - Aux 5: 52A