

EVELYN O. SHAW, COMMISSIONER
RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
CHRISTOPHER G. DAVIS, COMMISSIONER
TIMOTHY L. BRYANT, CEO/GENERAL MANAGER



FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

April 9, 2026

To: Potential Surplus Transformer Bidders
From: Paula Eckard, Supply Chain Analyst
CC: Elbert Norris, Apparatus Repair Shop Supervisor
Subject: Bid No. PWC2526083 for Surplus Transformer Shipment #707

Fayetteville Public Works Commission hereinafter referred to as Commission manages and controls various pieces of equipment. As the legal title holder of equipment, the Commission has approved the sale of equipment by sealed bid. The surplus transformer shipment #707 consists of one (1) lot of seventy-five (75) Overhead transformers, totaling 2202 KVA.

The Commission will accept sealed bids for this equipment until 2:00 p.m., Wednesday, April 22, 2026, at Fayetteville PWC, PO Box 1089, Fayetteville, NC 28301 or 1097 Public Works Drive, Fayetteville, NC 28301 Attn: Paula Eckard. All bids received shall be opened in public and the amount of each bid announced and recorded.

In order for a bid to be considered, the bidder must be pre-qualified to dispose of transformers. Bidding information may be viewed online at <https://www.faypwc.com/bids/>

The Commission reserves the right to withdraw the equipment from sale at any time and the right to reject any and all bids, waive all informalities concerning a bid or award a bid to the highest responsible bidder.

The successful bidder must remit payment within 30 calendar days from the bid award. The PWC Supply Chain Department accepts wire transfers, certified checks, or money orders as forms of payment. All items must be picked up from the PWC within 10 business days after receipt of payment. The PWC does provide loading, packing, shipping, and/or labor assistance for pickups. The successful bidder must arrange and perform all necessary transportation to ship, and/or remove the items. Property may be removed between the hours of 9:00 a.m. to 12:00 p.m. or 1:00 p.m. to 4:00 p.m. Monday through Friday, excluding State holidays.

Inquiries concerning the bidding process may be made to paula.eckard@faypwc.com, if you have prequalification or technical questions about the units offered, please contact elbert.norris@faypwc.com.

BUILDING COMMUNITY CONNECTIONS SINCE 1905

AN EQUAL EMPLOYMENT OPPORTUNITY EMPLOYER

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu.	Date O.S.	Co #	YMFG	2025
1	65AE12830	15	1-295-025	7200	240/480	N	Conv.	375	2603639-01	<1.0	WH	9/18/25	012827	1965	60
2	27B5921842	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2603542-02	<1.0	ER	9/24/25	035427	1998	27
3	16A5275728	25	1-295-370	7.2x14.4	120/240	G	CSP	435	2603542-02	<1.0	ER	9/24/25	033886	1997	28
4	69AM13464	50	1-295-395	7200	120/240	G	CSP	656	2600351-02	<2.1	WH	9/15/25	008845	1969	56
5	03A5110101	50	1-295-400	7.2x14.4	120/240	G	CSP	645	2600351-02	<1.0	ER	9/15/25	033765	1997	28
6	"0038026555	167	1-295-142	7200	120/240	G	Conv.	1783	2602842-02	<1.0	CP	9/25/25	036763	2000	25
7	03A5110110	50	1-295-400	7.2x14.4	120/240	G	CSP	645	2502204-02	<1.0	ER	10/9/25	033760	1997	28
8	71AH19123	15	1-295-340	7200	120/240	G	CSP	310	2604256-01	<1.0	WH	10/6/25	018299	1971	54
9	97A282026	50	1-295-400	7.2x14.4	120/240	G	CSP	622	2502204-02	<1.0	AB	10/9/25	034175	1997	28
10	03A5110100	50	1-295-400	7.2x14.4	120/240	G	CSP	645	2502204-02	<1.0	ER	10/9/25	033766	1997	28
11	48A5578531	25	1-295-370	7.2x14.4	120/240	G	CSP	410	2604117-01	<1.0	ER	10/3/25	034912	1997	28
12	Q361738YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2602432-02	<1.0	GE	10/2/25	031504	1994	31
13	90107397350	25	1-295-365	7200	120/240	G	CSP	373	2602101-02	<1.0	ER	8/18/25	038559	2001	24
14	97A281506	50	1-295-400	7.2x14.4	120/240	G	CSP	622	2604117-01	<1.0	AB	10/2/25	034185	1997	28
15	71AC11526	25	1-295-365	7200	120/240	G	CSP	421	2602487-02	<1.0	WH	10/8/25	011082	1971	54
16	91NE204001	10	1-295-331	7.2x14.4	120/240	G	CSP	297	2602582-02	<1.0	CP	11/4/25	027830	1991	34
17	1412173990	10	1-295-331	7.2x14.4	120/240	G	CSP	311	2602487-02	<1.0	HI	10/8/25	027400	1990	35
18	48A5578611	25	1-295-370	7.2x14.4	120/240	G	CSP	410	2601729-02	<1.0	ER	10/30/25	034965	1997	28
19	Q361834-YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2604861-01	<1.0	GE	10/24/25	031613	1994	31
20	94A064658	25	1-295-370	7.2x14.4	120/240	G	CSP	300	2600985-02	<1.0	AB	10/31/25	030886	1994	31
21	71AH19132	15	1-295-340	7200	120/240	G	CSP	297	2602589-02	<1.0	WH	11/4/25	013716	1971	54
22	4004032884	25	1-295-365	7200	120/240	G	CSP	460	2600660-02	<1.0	KU	11/4/25	022768	1984	41
23	Q361845-YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2601676-02	<1.0	GE	10/30/25	031498	1979	46
24	98A391760	25	1-295-370	7.2x14.4	120/240	G	CSP	425	2602086-02	<1.0	AB	10/31/25	035629	1998	27
25	20407783171	10	1-295-330	7200	120/240	G	CSP	272	2602127-02	<1.0	ER	9/8/25	040777	2004	21
26	98A391708	25	1-295-370	7.2x14.4	120/240	G	CSP	450	2604421-02	<1.0	AB	10/15/25	035632	1998	27
27	74AB3924	100	1-295-100	7200	120/240	G	Conv.	1015	2602842-02	<1.0	WH	9/25/25	007537	1974	51
28	94NA263017	10	1-295-331	7.2x14.4	120/240	G	CSP	400	2604418-02	<1.0	CP	10/1/25	030773	1994	31
29	81A303269	50	1-295-395	7200	120/240	G	CSP	755	2604394-01	<1.0	WH	10/13/25	017086	1995	30
30	07B5628865	25	1-295-370	7.2x14.4	120/240	G	CSP	385	2602546-02	<1.0	ER	10/8/25	035152	1998	27
31	74AF5999	25	1-295-365	7200	120/240	G	CSP	421	2604240-02	<1.0	WH	10/13/25	0102AD	1974	51
32	48A5578609	25	1-295-370	7.2x14.4	120/240	G	CSP	410	2601880-02	<1.0	ER	9/2/25	034990	1997	28
33	04A5137037	10	1-295-331	7.2x14.4	120/240	G	CSP	275	2602361-02	<1.0	ER	9/19/25	033719	1997	28
34	27B5921864	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2602251-02	<1.0	ER	9/2/25	035480	1998	27
35	87NG242029	50	1-295-400	7.2x14.4	120/240	G	CSP	693	2603614-01	<1.0	ME	9/26/25	025149	1987	38
36	N858437YMX	50	1-295-405	14400	120/240	G	CSP	600	2602073-02	<1.0	GE	9/4/25	023210	1985	40
37	92A122225	25	1-295-370	7.2x14.4	120/240	G	CSP	400	2603430-02	<1.0	AB	9/12/25	028617	1992	33
38	72AH7725	50	1-295-405	14400	120/240	G	CSP	665	2603339-01	<1.0	WH	9/9/25	002409	1972	53
39	M21C28801	50	1-295-395	7200	120/240	N	CSP	266	2603266-01	<1.0	GE	9/6/25	053681	2021	4
40	871114968	25	1-295-370	7.2x14.4	120/240	G	CSP	425	2601735-02	<1.0	RT	9/9/25	025403	1987	38
41	3394974494	10	1-295-331	7.2x14.4	120/240	G	CSP	311	2604168-02	<1.0	HI	12/10/25	032216	1994	31
42	71AJ17189	25	1-295-365	7200	120/240	G	CSP	450	2606475-01	6.7	WH	12/19/25	014158	1971	54
43	6594251	5	1-295-315	7200	120/240	G	CSP	300	2604709-02	18.7	WH	12/11/25	008268	1965	60
44	72AC11481	15	1-295-355	14400	120/240	G	CSP	311	2507178-02	<1.0	WH	10/11/25	012190	1972	53
45	"0086569	15	1-295-340	7200	120/240	G	CSP	400	2605573-02	<1.0	AC	12/4/25	007917	1969	56
46	27B5921830	10	1-295-331	7.2x14.4	120/240	N	CSP	240	2606017-01	<1.0	ER	11/30/25	035454	1998	27
47	93NJ373046	25	1-295-370	7.2x14.4	120/240	G	CSP	468	2604751-02	<1.0	CP	12/10/25	030252	1993	32
48	34W3528805	50	1-295-403	7.2x14.4	120	G	CSP	660	2507802-03	<1.0	ER	11/16/25	030146	1993	32
49	94NA263052	10	1-295-331	7.2x14.4	120/240	G	CSP	283	2604751-02	<1.0	CP	11/19/25	030774	1994	31
50	97NH483058	10	1-295-331	7.2x14.4	120/240	G	CSP	400	2603508-01	<1.0	CP	11/12/25	034378	1997	28
51	40407816605	50	1-295-066	14.4x7.2	277	G	Conv.	823	2602830-02	<1.0	ER	11/13/25	040794	2004	21
52	93NH345036	10	1-295-331	7.2x14.4	120/240	G	CSP	302	2603776-01	<1.0	CP	11/13/25	030076	1993	32
53	69AH10897	25	1-295-365	7200	120/240	G	CSP	400	2601890-02	<1.0	WH	11/14/25	011094	1986	39
54	3128431	10	1-295-330	7200	120/240	G	CSP	400	2502204-02	1	AC	10/20/25	002649	1958	67
55	68AK6522	25	1-295-365	7200	120/240	G	CSP	500	2604314-02	1.5	WH	10/29/25	013735	1968	57
56	34W3528800	50	1-295-403	7.2x14.4	120	G	CSP	660	2507802-03	<1.0	ER	11/16/25	030145	1993	32
57	N967801-YHY	75	1-295-415	7200	120/240	G	CSP	800	2604314-02	<1.0	GE	10/29/25	023454	1993	32
58	88A511615	25	1-295-370	7.2x14.4	120/240	G	CSP	600	2604805-02	<1.0	WH	11/20/25	026013	1988	37
59	901004460	10	1-295-331	7.2x14.4	120/240	G	CSP	283	2507178-02	<1.0	RT	11/19/25	026914	1990	35
60	40407816603	50	1-295-066	14.4x7.2	277	G	Conv.	823	2602830-02	<1.0	ER	11/13/25	040792	2004	21
61	01A031798	10	1-295-330	7200	120/240	G	CSP	202	2605700-01	<1.0	AB	11/24/25	037637	1998	27
62	C1610566816	10	1-295-330	7200	120/240	G	CSP	259	2605448-01	<1.0	ER	11/13/25	050599	2016	9
63	85A250918	50	1-295-395	7200	120/240	G	CSP	550	2602996-02	<1.0	WH	11/13/25	023355	1985	40
64	40407816602	50	1-295-066	14.4x7.2	277	G	Conv.	823	2602830-02	<1.0	ER	11/13/25	040791	2004	21
65	34W3528803	50	1-295-403	7.2x14.4	120	G	CSP	660	2507802-03	<1.0	ER	11/16/25	030144	1993	32
66	94A084418	25	1-295-370	7.2x14.4	120/240	G	CSP	425	2604751-02	<1.0	AB	11/14/25	030937	1994	31
67	97NH483035	10	1-295-331	7.2x14.4	120/240	N	CSP	380	Training Yard	<1.0	CP	1/6/26	034448	1997	28
68	74AJ6575	50	1-295-395	7200	120/240	N	CSP	480	Training Yard	<1.0	WH	1/6/26	74AJ6575	1974	51
69	97NN812067	10	1-295-331	7.2x14.4	120/240	N	CSP	380	Training Yard	<1.0	CP	1/6/26	034783	1997	28
70	91NL644024	10	1-295-331	7.2x14.4	120/240	N	CSP	380	Training Yard	<1.0	CP	1/6/26	028373	1991	34
71	97NH483069	10	1-295-331	7.2x14.4	120/240	N	CSP	380	Training Yard	<1.0	CP	1/6/26	034433	1997	28
72	91NE204021	10	1-295-331	7.2x14.4	120/240	N	CSP	380	Training Yard	<1.0	CP	1/6/26	91NE204021	1991	34

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu.	Date O.S.	Co #	YMFG	2025
73	871112361	10	1-295-331	7.2x14.4	120/240	N	CSP	380	Training Yard	<1.0	RT	1/6/26	871112361	1987	38
74	71AJ17189	25	1-295-365	7200	120/240	G	CSP	450	2606475-01	6.7	WH	12/19/25	014158	1971	54
75	00A232139	10	1-295-015	7200	120/240	N	Conv.	380	Training Yard	<1.0	AB	1/6/26	036833	1995	30

Total KVA = 2202.0

Total Lbs= 36014

AVG= 35
 Total Units >= 30 years 46
 Total Units >=20 and <= 30 29
 Total Units < 20 2
Total = 75

5 Kva total=	5
10 Kva total=	230
15 Kva total=	75
25 Kva total=	600
50 Kva total=	950
75 Kva total=	75
100 Kva total=	100
167 Kva total=	167
Total KVA	2202.0

1-295-100	1
1-295-025	1
1-295-066	3
1-295-015	1
1-295-142	1
1-295-205	0
1-295-220	0
1-295-315	1
1-295-330	4
1-295-331	18
1-295-340	3
1-295-355	1
1-295-365	8
1-295-370	16
1-295-375	0
1-295-395	5
1-295-400	6
1-295-403	3
1-295-405	2
1-295-415	1

N
G

Total Bad Unit= 11
 Total Operational Units= 64
Total= 75

Mfg Totals

AC	2
ABB	9
COOPER	12
ERMCO	21
GE	6
HOWARD	2
KUHLMAN	1
Mcgraw/Edison	1
RTE	3
WEST	18
PAUW	0

Total= 75

Total# 5 Kva =	1
Total# 10 Kva =	23
Total# 15 Kva =	5
Total# 25 Kva =	24
Total# 50 Kva =	19
Total# 75 Kva =	1
Total# 100 Kva =	1
Total# 167 Kva =	1

Total 75

Total# Units 75

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

①

Nameplate Data				Equipment Information	
Serial Number	65AE12830	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316732	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

2

Nameplate Data			
Serial Number	27B5921842	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	10
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	10/03/2025	
Barcode Sample Number	00316731	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

3

Nameplate Data			
Serial Number	16A5275728	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	10/03/2025	
Barcode Sample Number	00316730	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

4

Nameplate Data				Equipment Information	
Serial Number	69AM13464	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316735	
PCB (D4059)	ppm	2.1
Oil Quality	Fluid test as Non-PCB.	

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

5

Nameplate Data				Equipment Information	
Serial Number	03A5110101	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316736	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

6

Nameplate Data				Equipment Information	
Serial Number	0038026555	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	167	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/02/2026
Barcode Sample Number	00316587
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

7

Nameplate Data				Equipment Information	
Serial Number	03A5110110	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316682	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

8

Nameplate Data				Equipment Information	
Serial Number	71AH19123	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316693	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

9

Nameplate Data | **Equipment Information**

Serial Number	97A282026	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date 10/27/2025

Barcode Sample Number 00316681

PCB (D4059) ppm < 1
Oil Quality Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

10

Nameplate Data				Equipment Information	
Serial Number	03A5110100	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316683	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

(11)

Nameplate Data				Equipment Information	
Serial Number	48A5578531	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316698	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH

*



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

12

Nameplate Data			Equipment Information		
Serial Number	Q361738YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025
Barcode Sample Number	00316700
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number 90107397350 Unit ID OH
Equipment Type Transformer Manufacturer
Year Manufactured Primary KV
Gallons KVA Rating 25
Phases 1 Fluid type Mineral Oil
Substation Apparatus Breathing
Location Configuration

Equipment Information

Top Valve (in) Bottom Valve (in)
Hose Length (ft) Paint Condition
Conservator Tank Bushings Enclosed
Leaks Radiators
Service Energized Compartments

13

Sample Date 10/27/2025

Barcode Sample Number 00316703

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

14

Nameplate Data			Equipment Information		
Serial Number	97A281506	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316699	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

15

Nameplate Data			Equipment Information		
Serial Number	71AC11526	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316684	
PCB (D4059)	ppm	3.8
Oil Quality	Fluid test as Non-PCB.	

7070H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

18

Nameplate Data			Equipment Information		
Serial Number	91NE204001	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025
Barcode Sample Number	00316652
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

17

Nameplate Data			Equipment Information		
Serial Number	1412173990	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025
Barcode Sample Number	00316686
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

18

Nameplate Data			Equipment Information		
Serial Number	48A5578611	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025
Barcode Sample Number	00316654
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

19

Nameplate Data			Equipment Information		
Serial Number	Q361834-YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316674	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

20

Nameplate Data			Equipment Information		
Serial Number	94A064658	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316653	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

21

Nameplate Data			Equipment Information		
Serial Number	71AH19132	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316651	
PCB (D4059)	ppm	7.7
Oil Quality	Fluid test as Non-PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

22

Nameplate Data			Equipment Information		
Serial Number	4004032884	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025
Barcode Sample Number	00316650
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 0+1



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

23

Nameplate Data				Equipment Information	
Serial Number	Q361845-YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316678	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 041



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

24

Nameplate Data				Equipment Information	
Serial Number	98A391760	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025
Barcode Sample Number	00316677
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

25

Nameplate Data				Equipment Information	
Serial Number	20407783171	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025
Barcode Sample Number	00316672
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

(26)

Nameplate Data				Equipment Information	
Serial Number	98A391708	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316657	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

27

Nameplate Data				Equipment Information	
Serial Number	.74AB3924	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	100	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316656	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 041



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

28

Nameplate Data			Equipment Information		
Serial Number	94NA263017	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316658	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

29

Nameplate Data				Equipment Information	
Serial Number	81A303269	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	11/10/2025	
Barcode Sample Number	00316655	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 041



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

30

Nameplate Data			Equipment Information		
Serial Number	07B5628865	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316687	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 0+1



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

31

Nameplate Data				Equipment Information	
Serial Number	74AF5999	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/27/2025	
Barcode Sample Number	00316685	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

32

Nameplate Data				Equipment Information	
Serial Number	48A5578609	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025
Barcode Sample Number	00316750
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

33

Nameplate Data				Equipment Information	
Serial Number	04A5137037	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date		10/03/2025
Barcode Sample Number		00316734
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

707 OH




Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

34

Nameplate Data				Equipment Information	
Serial Number	27B5921864	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316749	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

35

Nameplate Data			
Serial Number	87NG242029	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	50
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information		
Top Valve (in)	Bottom Valve (in)	
Hose Length (ft)	Paint Condition	
Conservator Tank	Bushings Enclosed	
Leaks	Radiators	
Service Energized	Compartments	

Sample Date	10/03/2025	
Barcode Sample Number	00316716	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

36

Nameplate Data				Equipment Information	
Serial Number	N858437YMX	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316747	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

37

Nameplate Data				Equipment Information	
Serial Number	92A122225	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025
Barcode Sample Number	00316737
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 04



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

38

Nameplate Data				Equipment Information	
Serial Number	72AH7725	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316742	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 0+1



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

39

Nameplate Data				Equipment Information	
Serial Number	M21C28801	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	10/03/2025
Barcode Sample Number	00316744
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data | **Equipment Information**

Serial Number	871114968	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

40

Sample Date 10/03/2025

Barcode Sample Number 00316740

PCB (D4059) ppm < 1
Oil Quality Fluid test has No PCB.

#707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

41

Nameplate Data				Equipment Information	
Serial Number	3394974494	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/02/2026	
Barcode Sample Number	00316583	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

42

Nameplate Data				Equipment Information	
Serial Number	71AJ17189	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	01/28/2026	
Barcode Sample Number	00316568	
PCB (D4059)	ppm	6.7
Oil Quality	Fluid test as Non-PCB.	

707 0+1



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

43

Nameplate Data				Equipment Information	
Serial Number	6594251	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	5	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	01/02/2026	
Barcode Sample Number	00316585	
PCB (D4059)	ppm	18.7
Oil Quality	Fluid test as Non-PCB.	

#707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

44

Nameplate Data				Equipment Information	
Serial Number	72AC11481	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/02/2026	
Barcode Sample Number	00316584	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

45

Nameplate Data				Equipment Information	
Serial Number	0086569	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/02/2026	
Barcode Sample Number	00316580	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	27B5921830	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	10
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

46

Sample Date 01/02/2026

Barcode Sample Number 00316578

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

707 041



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

47

Nameplate Data				Equipment Information	
Serial Number	93NJ373046	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/02/2026	
Barcode Sample Number	00316586	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

48

Nameplate Data				Equipment Information	
Serial Number	34W3528805	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316607
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

7070H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

49

Nameplate Data				Equipment Information	
Serial Number	94NA263052	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316599	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

50

Nameplate Data			Equipment Information		
Serial Number	97NH483058	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316614
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

#707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

51

Nameplate Data			Equipment Information		
Serial Number	40407816605	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316620	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

52

Nameplate Data				Equipment Information	
Serial Number	93NH345036	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316618
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

#707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

53

Nameplate Data				Equipment Information	
Serial Number	69AH10897	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316616
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

54

Nameplate Data				Equipment Information	
Serial Number	3128431	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316613
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

55

Nameplate Data				Equipment Information	
Serial Number	68AK6522	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316612	
PCB (D4059)	ppm	1.5
Oil Quality		Fluid test as Non-PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

56

Nameplate Data				Equipment Information	
Serial Number	34W3528800	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316606	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

7070H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

57

Nameplate Data				Equipment Information	
Serial Number	N967801-YHY	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	75	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316610
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

58

Nameplate Data | **Equipment Information**

Serial Number	88A511615	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date 12/02/2025

Barcode Sample Number 00316601

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data

Serial Number	901004460	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	10
Phases	1	Fluid type	Mineral Oil
Substation Location	Apparatus	Breathing Configuration	

Equipment Information

Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

59

Sample Date 12/02/2025

Barcode Sample Number 00316600

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

60

Nameplate Data				Equipment Information	
Serial Number	40407816603	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316619
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

61

Nameplate Data			Equipment Information		
Serial Number	01A031798	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316603	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 0+1



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

62

Nameplate Data | **Equipment Information**

Serial Number	C1610566816	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date 12/02/2025

Barcode Sample Number 00316598

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

#707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

63

Nameplate Data				Equipment Information	
Serial Number	85A250918	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316615	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

(64)

Nameplate Data				Equipment Information	
Serial Number	40407816602	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316617
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

65

Nameplate Data				Equipment Information	
Serial Number	34W3528803	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025	
Barcode Sample Number	00316608	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

66

Nameplate Data				Equipment Information	
Serial Number	94A084418	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	12/02/2025
Barcode Sample Number	00316609
PCB (D4059) ppm	< 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

67

Nameplate Data				Equipment Information	
Serial Number	97NH483035	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/28/2026
Barcode Sample Number	00316562
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

68

Nameplate Data				Equipment Information	
Serial Number	74AJ6575	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/28/2026	
Barcode Sample Number	00316563	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

69

Nameplate Data | **Equipment Information**

Serial Number	97NN812067	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date 01/28/2026

Barcode Sample Number 00316559

PCB (D4059) ppm < 1
Oil Quality Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

70

Nameplate Data				Equipment Information	
Serial Number	91NL644024	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	01/28/2026	
Barcode Sample Number	00316556	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

(71)

Nameplate Data				Equipment Information	
Serial Number	97NH483069	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/28/2026
Barcode Sample Number	00316558
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

72

Nameplate Data				Equipment Information	
Serial Number	91NE204021	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/28/2026	
Barcode Sample Number	00316557	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

707 04



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

73

Nameplate Data | **Equipment Information**

Serial Number	871112361	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date 01/28/2026

Barcode Sample Number 00316555

PCB (D4059) ppm < 1

Oil Quality Fluid test has No PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

74

Nameplate Data				Equipment Information	
Serial Number	71AJ17189	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date	01/28/2026
Barcode Sample Number	00316568
PCB (D4059) ppm	6.7
Oil Quality	Fluid test as Non-PCB.

707 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

75

Nameplate Data | **Equipment Information**

Serial Number	00A232139	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date 01/28/2026

Barcode Sample Number 00316561

PCB (D4059) ppm < 1
Oil Quality Fluid test has No PCB.



Surplus Transformer Shipment Lot 707

Due April 16, 2026

PWC2526083 Bid Pricing Form

Bidders Information

Bidders Name: _____

Street Address: _____

Telephone Number: _____

Email: _____

Print Name and Title: _____

Bidders Authorized Signature: _____

Date: _____

Pricing

LOT	QTY <i>(LOT KVA TOTAL)</i>	UNIT COST	EXTENDED COST
707	2202		