



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2425077 - REBID

Bid Title: Three (3) Continuous Rated 67 KV Delta to 13.09 Y/7.56KV With LTC Rated 24/35.8/44.8 MVA Power Transformers at ONAN, ONAF, ONAF

Bid Opening Date and Time: Thursday, April 30, 2026 @ 2:00 P.M.

Addendum Number: 1

Addendum Date: April 16, 2026

Procurement Advisor: *Lacoma Jones*
Procurement@faypwc.com

1. Addenda acknowledgement is required within the IFB Bid Pricing Form.
2. The solicitation is hereby modified as follows:
 - M1. Bid Pricing Form:** The bid form has been updated and replaced, as attached to Addendum No. 1.
3. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** Would you please reply if you need Bid Bond for the Project? If, Yes, what % of bond required?
A1. Yes, a 5% bid bond is required.
 - Q2.** To best prepare our proposal, could you disclose the reason for the rebid?
A2. All previous bids did not meet bid requirements or bid specifications.
 - Q3.** We understand that, according to IFB, Section 5.8.2, 5.9.1, 5.10.1, 5.12, 5.13, 5.15.6, 12,13 of Attachment A Technical Specifications indicate that certain manufacturers for each component are designated. We also understand that those specifications can be varied upon approval from PWC. In terms of that, can we assume that we can propose the alternatives for those above-mentioned items?
A3. No, PWC is not able to accept alternatives for the items listed.
 - Q4.** Will PWC accept items from a manufacturer that is outside of North America?
A4. No, PWC will not accept items from manufacturers located outside of North America.
 - Q5.** Will PWC be able to grant a 2 weeks extension to prepare and submit a competitive proposal to the Commission?
A5. At this time, PWC is unable to grant a two-week extension.
 - Q6.** Will PWC consider for award manufacturers including these components sourced from other countries/manufacturers in its base bid?
A6. PWC will not consider bids from manufacturers located outside of North America for this solicitation. Based on prior evaluation considerations, PWC has determined that limiting eligible manufacturers to those located within North America is necessary to ensure adequate verification of manufacturing processes, quality control standards, and logistical reliability.
 - Q7.** Will PWC accept redlines over the general terms and conditions of the contract and eventually negotiate with the prospective awardee the final wording acceptable for both parties of the given clauses?
A7. All contract modification requests should be specified on Attachment H: Form of Exceptions – Sale of Goods Agreement. If, in submitting this bid, the bidder has made any exceptions to bid

documents, the bidder understands that PWC will evaluate the effect of such exceptions or variations in determining responsiveness and award eligibility

- Q7.** Attachment B: BID PRICING FORM shows, at the end of page 62, asks for "Manufacturer's Field Service Engineer" for the time outlined in two blank fields, which include "kW" at the end, to complete with "No. Of Days Per Unit" and a "Daily Rate". Please correct the unit as it is clearly a typo.
- A7.** Refer to Modification 1 in this Addendum No. 1.
- Q7.** Will PWC provide a link so that bidders can attest bid opening virtually?
- A7.** This bid opening does not have an option for a virtual bid opening.
- Q7.** Is there any flexibility regarding the delivery date?
- A7.** Yes, PWC has flexibility regarding the proposed delivery date. Delivery dates later than April 21, 2028, may be considered during the evaluation process.
- Q7.** How much will the lead time affect the outcome of the award?
- A7.** As outlined in the Bid Document (pages 8–9), the evaluation will take into account lead times and firm pricing, in addition to the bid price. Proposals offering competitive firm pricing or overall value may be favorably considered even if a longer delivery timeframe is proposed.

Attachments:

Bid Pricing Form

ATTACHMENT B: BID PRICING FORM

Bidder Information:

Name of Company _____

Company Location _____

Phone Number _____

Email Address _____

Manufacturer _____

Manufacturer Location _____

Is the company an N.C. Certified HUB or DBE _____

Printed Name _____

Title _____

Authorized Signature _____

Date _____

Bidders shall submit pricing exclusively on the Bid Pricing Forms provided in this IFB, or on exact copies thereof. The Bid Pricing Form must be fully completed and properly executed. Failure to provide a complete submission will result in the bid being deemed non-responsive, as PWC will lack the necessary information to conduct a proper evaluation. A fully completed Bid Pricing Form includes the bidder’s company name, company location, and email address; the name and location of the manufacturer; the bidder’s NC HUB or DBE certification status (if applicable); and the printed name, title, signature, and date of an authorized company representative. Bidders must also provide part numbers, lead times, unit prices, extended prices for each line item, and acknowledgment of all issued addenda. All pricing must remain valid for a minimum of sixty (60) calendar days from the date of bid opening and shall be F.O.B. Destination.

Furnish And Deliver:

| Item # | QTY. | UOM | DESCRIPTION | UNIT PRICE |
|--------|------|------|---|------------|
| 1 | 3 | E.A. | Continuous Rated 67kv Delta To 13.09 Y/7.56kv With LTC 24/35.8/44.8 MVA Power Transformers At ONAN, ONAF, ONFAF Part Number: _____ Lead Time: _____ | \$ |

TOTAL EXTENDED BID \$ _____

Tariff Disclosure Section:

1. Are any tariffs included in the Bid Price?
 Yes No

2. If yes, complete the table below for each tariff-impacted line item or component included in this bid:

| | | | |
|---|--|--|--|
| Line Item / Component | | | |
| Country of Origin | | | |
| Base Cost of Affected Component (Included in Bid) | | | |
| Tariff % Applied at Bid | | | |
| Tariff Cost Included in Bid | | | |

3. Percentage of total bid price attributable to tariffs: _____%

4. Total tariff cost included in this bid: \$_____

5. The Bidder certifies that the tariff values identified above reflect the tariff cost included in the bid price as of the bid due date and shall serve as the baseline for any future tariff adjustment request under **Attachment C: Tariff Price Adjustments**.

Signature: _____ Date: _____

The Bidder has received, acknowledged, and used the following addenda in completing the Bid. (Initial and Date as appropriate).

| | |
|----------------|------------|
| Addendum No. 1 | Date _____ |
| Addendum No. 2 | Date _____ |
| Addendum No. 3 | Date _____ |
| Addendum No. 4 | Date _____ |
| Addendum No. 5 | Date _____ |
| Addendum No. 6 | Date _____ |
| Addendum No. 7 | Date _____ |

MAXIMUM GUARANTEED LOSSES

SCHEDULES 1⁽¹⁾

| | LTC 1R Pos | LT C ⁽²⁾ Avg. 15R & 16R Pos |
|---|---------------|---|
| Maximum guaranteed no-load kW losses, 100% voltage, 75°C, 50 MVA(3) | kW | kW |
| Maximum guaranteed load kW losses, (not total losses) at 50 MVA(3) | kW | kW |
| Maximum guaranteed Total kW losses, at 50 MVA, 75°C(3) | kW | kW |
| Auxiliary kW losses, first stage cooling | kW | kW |
| Auxiliary kW losses, second stage cooling | kW | kW |
| Impedance % | % | % |

MAXIMUM GUARANTEED PCB DIELECTRIC LEVEL (1)

Measured at the factory prior to oil filling of the transformer _____ PPM

Measured at the site after oil filling of the transformer _____ PPM

- (1) All transformers in all bid schedules shall conform to these losses and values.
- (2) These levels will be considered in evaluating the bids.
- (3) No-load and total losses are to be guaranteed per ANSI or IEEE standards.

Delivery (Weeks)*

Bid Schedule No. 1

Approval Drawings** _____

Final Drawings** _____

Delivery** _____

The base quotation shall include the services of a Manufacturer's Field Service Engineer for the time outlined below per unit. Extra days (or credit for days not used) shall be supplied at a daily rate as quoted below:

| Item | No. of Days Per Unit | Daily Rate* |
|-----------------------|----------------------|-------------|
| LTC Power Transformer | _____ | \$ _____ |

*Adjustment for exceeding five (5) days or credit for less than three (3) days.