



Bid Tabulation
PWC2526025 - Two (2) 230KV SF6 Gas Breakers For POD 5
Bid Opening: November 4, 2025 @ 1:00 pm

BIDDER NAME		Siemens Energy, Inc.	
CITY/STATE		Richland, MS	
MANUFACTURER		Siemens Energy, Inc.	
HUB/DBE		No	
LEAD TIMES		145 weeks	
DESCRIPTION	QTY	UOM	UNIT PRICE EXTENDED
Two (2) Circuit Breakers Gang Operated rated 230 kV nominal, 245 kV maximum, 3000 amperes continuous current carrying capacity at 60 Hertz with a minimum of 63,000 amperes symmetrical interrupting rating, 900 kV BIL furnished with three (3) sets of 3000:5 C800 relay ratio current transformers, and one (1) set of 600/1200:5 dual tap ratio metering accuracy current transformers	2	EA	\$ 238,900.00 \$ 477,800.00
Manufacturer			Siemens
Type			SPS2S-245-63-3000
Lead Time			145 WEEKS
TOTAL			\$ 477,800.00

Disclaimer: Inclusion of a bid on the bid tab does not indicate that the bid is being considered for award. The bid tab simply represents sealed bids that were submitted on time using the PWC bid pricing form (Attachment B) before the bid opening date/time. All bids are subject to further review and evaluation for compliance with the solicitation requirements.