



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2526058 REBID

Bid Title: GRADING FOR THE POINT OF DELIVERY 5

Bid Opening Date and Time: Thursday, May 28, 2026, 2:00 p.m.

Addendum Number: 2

Addendum Date: Wednesday, May 20, 2026

Procurement Advisor: *Jarvis Brown*
procurement@faypwc.com



-
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
 2. The solicitation is hereby modified as follows:
 - M1. APPENDICES** – Appendix 5: All Weather Access Drive and Pad – has been added to the contract documents and attached to this Addendum No. 2.
 - M2. BID SCHEDULE – BID OPENING:** The IFB Schedule has been revised to extend the Bid Opening Pursuant to N.C.G.S 143-129, sealed bids are solicited and will be received at Fayetteville Public Works Commission, Administration Building, Conference Room 230, 955 Old Wilmington Road, Fayetteville, NC 28301, until **2:00 p.m., EST May 28, 2026**, at which time they will be publicly opened and read.

Attachments:

Appendix 5: All Weather Access Drive and Pad

NOTES:

1. ALL WEATHER ACCESS SHOULD ONLY BE INSTALLED WHEN REGULAR ACCESS WITH A TWO-WHEEL DRIVE VEHICLE CANNOT ACCESS THE SWITCH LOCATION DURING HEAVY RAIN SEASONS.
3. ALL REQUIRED DOCUMENTATION INCLUDING 3RD PARTY ACCESS AGREEMENTS AND ACCESS EASEMENT SHALL BE FILED WITH THE APPROPRIATE PARTIES (PROJECT MANAGEMENT, TRANSMISSION ASSET PROTECTION, LAND SERVICES, AND SITING & ENVIRONMENTAL PERMITTING).
5. ALL AGREEMENTS PERTAINING TO ALL WEATHER ACCESS MUST BE OBTAINED PRIOR TO CONSTRUCTION CLOSEOUT. IN SOME CASES, MULTIPLE AGREEMENTS MAY NEED TO BE ACQUIRED FROM ALL LAND OWNERS.
7. ALL ENVIRONMENTAL PERMITTING SHALL BE OBTAINED PRIOR TO START OF CONSTRUCTION.
8. DESIGNS FOR "ALL WEATHER ACCESS" TO TRANSMISSION LINE SWITCHES MUST BE REVIEWED BY TRANSMISSION ASSET PROTECTION PRIOR TO ISSUING FOR CONSTRUCTION.
9. CULVERTS SHALL BE INSTALLED AS NEEDED AS REQUIRED TO ALLOW PROPER DRAINAGE. ALL CULVERT DESIGNS SHALL BE ABLE TO WITHSTAND UP TO 80K LBS GVWR.
10. AT LOCATION OF CULVERTS, A DEPRESSION SHALL BE CUT INTO THE SURFACE OF THE ACCESS AREA TO ALLOW WATER TO FLOW OVER THE DURING FLOODS (TO BE DETERMINED BY CIVIL ENGINEER).
11. PUBLIC ENGAGEMENT INVOLVEMENT MAY BE NEEDED. LAND SERVICES TO VERIFY EASEMENT RIGHTS BEFORE CONSTRUCTION. (COPY PROJECT MANAGER ON ANY CORRESPONDENCE WITH LAND OWNER).
12. ALL PERMITS MUST BE OBTAINED BEFORE CONSTRUCTION TO BEGIN.
13. ALL WEATHER ACCESS PHYSICAL BOUNDARIES SHALL BE CONTAINED WITHIN DEP ROW LIMITS. IF THIS IS NOT POSSIBLE. ADDITIONAL RIGHTS FROM THE LANDOWNER WILL NEED TO BE ACQUIRED.
14. ALL SLOPES SHALL BE EQUAL TO OR LESS THAN A 4:1 SLOPE RATIO.
10. ALL WEATHER ACCESS TOP TO BE FINISHED WITH; ABC STONE, SEED AND NORTH AMERICAN GREEN S75 FABRIC OR EQUAL TO BE INSTALLED, AFTER ALL CONSTRUCTION HEAVY EQUIPMENT IS REMOVED FROM THE CONSTRUCTION SITE.
11. PERMANENT GRASSING MUST BE INITIATED PRIOR TO CONSTRUCTION CLOSEOUT.



GATE DETAIL

MAXIMO ID# 4030907 by PRIEFERT

GATE, ... FENCE, STEEL, TUBULAR, 16"X50" GALVANIZED 2" OD TUBULAR STEEL BULL GATE, 16' X 50", WITH 6 HORIZONTAL BARS AND 2 STABILIZER HARDWARE TO BE SUPPLIED INCLUDES ONE UPPER ADJUSTABLE HINGE, ONE LOWER WELDED HINGE, TWO 5/8" OR 3/4" LAG HINGE PINS, ONE WELDED LATCH, AND ONE CHAIN HOOK. HARDWARE SET IS TO BE WRAPPED AND ATTACHED TO EACH GATE.

ENVIRONMENTAL PERMITTING

THIS DRAWING OR BILL OF MATERIAL IS CONFIDENTIAL AND MAY NOT BE LOANED, REPRODUCED OR COPIED, EITHER WHOLLY OR IN PART, OR MADE PUBLIC IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF DUKE ENERGY CORPORATION.	DPT: PROD STDS	ALL WEATHER ACCESS	
	DES/CHK: MJR	ENVIRONMENTAL PERMITTING	
	DATE: 05/26/2021	SAMPLE DRAWING & GUIDELINES	
	SCALE: SHEET: NTS 1 OF 1	REV: 0	NOT USED FOR CONSTRUCTION
DUKE ENERGY PROGRESS	DWG NO: ALL_WTHR_ACCESS		

FILENAME: AllWeatherAccess - 08252021.dwg

REV 1: 08-25-2021, REVISED NOTE 11