



**FAYETTEVILLE PUBLIC WORKS COMMISSION**

**PROCUREMENT DEPARTMENT**

<https://www.faypwc.com/bids/>

**Bid Addendum**

**PWC Number:** PWC25260100

**Bid Title:** Cleaning and CCTV Inspection Services

**Bid Opening Date and Time:** June 11, 2026

**Addendum Number:** 1

**Addendum Date:** June 4, 2026

**Procurement Advisor:** *Lacoma Jones*  
*procurement@faypwc.com*

1. Addenda acknowledgement is required within the IFB Bid Pricing Form.
2. Following are questions received about the solicitation and the SME's answers to the questions
  - Q1.** What is the difference between light cleaning vs. heavy cleaning?
    - A1.** Light cleaning typically involves a single pass at a moderate speed, whereas heavy cleaning requires two or more passes at a slower speed with increased water pressure. Heavy cleaning may also include the removal of roots or grease in the mains.