



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2526092

Bid Title: Annual Underground Distribution Boring Construction Contract

Bid Due Date and Time: Thursday, July 30, 2026 @ 2:00 p.m.

Addendum Number: 1

Addendum Date: Thursday, July 23, 2026

Procurement Advisor: *Jarvis Brown*
procurement@faypwc.com

1. Return one properly executed copy of this addendum with bid submittal or prior to the Bid Due Date/Time listed above.
2. Following are questions received about the solicitation and the SME's answers to the questions.
 - Q1.** On the itemized bid sheets labeled Assembly Group 11 Duct/Conduit. What exactly are you asking price. Is this asking price the material or labor to install these fittings?
A1. This is for labor.
 - Q2.** Could we get clarification on the meaning of CU; Mud Removal, Cost for Dumping 1 Load of Mud? Is this for the hauling to storage tanks or is this for disposal at processing facility?
A2. The awarded contractor will be responsible for hauling their mud and disposal at a facility at their expense.
 - Q3.** During the pre-bid call it was mentioned that the couplings and elbows would be fused to the HDPE pipe. Is the glue specifically designed to connect HDPE to PVC an acceptable method as well?
A3. There is no glue. This is for fused coupling. It requires the company to have electric fusion machines (like model nupiindustrietaliane.com). We supply the butt fuse couplings, but not the no glue.
 - Q4.** I know that the pre-bid is next Thursday, but I would like to request an excel version of the pricing sheet if possible.
A4. An excel version of the pricing sheet will not be provided. Bidders shall enter their prices and extended prices within the provided bid forms.