



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2627011

Bid Title: Structures and Equipment for the POD 5 – McArthur Road Substation

Bid Opening Date and Time: October 6, 2026, at 3:00 p.m.

Addendum Number: 1

Addendum Date: September 24, 2026

Procurement Manager: *Nikole Bohannon*
procurement@faypwc.com

1. Addenda acknowledgement is required within the IFB Bid Pricing Form.
2. Following are questions received about the solicitation and the SME's answers to the questions
 - Q1.** Please clarify if Booth or the Bidder is responsible for the steel design. The specs (3.2.1) say Bidder is responsible, but Appendix 3 "Steel Weight Breakdown" would imply that Booth is designing those structures.
A1. Bidder is responsible for steel design; steel weight breakdown is to provide an idea of what's expected.
 - Q2.** Can someone clarify which structures go in which Schedule? Structures listed in section 5.0 Structural Steel do not match the structures in the Steel Weight Breakdown
A2. Refer to section 5.0 and BOM drawings as they are both correct.
 - Q3.** Do we need to quote every line item on pages 40 & 76 in the bid in order to be awarded?
A3. Yes, unless noted otherwise.