

RONNA ROWE GARRETT, COMMISSIONER
DONALD L. PORTER, COMMISSIONER
CHRISTOPHER G. DAVIS, COMMISSIONER
RICHARD W. KING, COMMISSIONER
TIMOTHY L. BRYANT, CEO/GENERAL MANAGER



FAYETTEVILLE PUBLIC WORKS COMMISSION
955 OLD WILMINGTON RD
P.O. BOX 1089
FAYETTEVILLE, NORTH CAROLINA 28302-1089
TELEPHONE (910) 483-1401
WWW.FAYPWC.COM

October 14, 2026

To: Potential Surplus Transformer Bidders
From: Paula Eckard, Supply Chain Analyst
CC: Elbert Norris, Apparatus Repair Shop Supervisor
Subject: Bid No. PWC2627020 for Surplus Transformer Shipment #711 Overhead

Fayetteville Public Works Commission hereinafter referred to as Commission manages and controls various pieces of equipment. As the legal title holder of equipment, the Commission has approved the sale of equipment by sealed bid. The surplus transformer shipment #711 consists of one (1) lot of seventy-five (75) Overhead, totaling 2279.5 KVA.

The Commission will accept sealed bids for this equipment until 1:30 p.m., Thursday, October 29, 2026, at Fayetteville PWC, PO Box 1089, Fayetteville, NC 28301 or 1097 Public Works Drive, Fayetteville, NC 23301 Attn: Paula Eckard. All bids received shall be opened in public and the amount of each bid announced and recorded.

In order for a bid to be considered, the bidder must be pre-qualified to dispose of transformers. Bidding information may be viewed online at <https://www.faypwc.com/bids/>

The Commission reserves the right to withdraw the equipment from sale at any time and the right to reject any and all bids, waive all informalities concerning a bid or award a bid to the highest responsible bidder.

The successful bidder must remit payment within 30 calendar days from the bid award. The PWC Supply Chain Department accepts wire transfers, certified checks, or money orders as forms of payment. Coordination for pick-up will be made with Paula Eckard, all items must be picked up from the PWC complex within 10 business days after receipt of payment. The PWC does provide loading, packing, shipping, and/or labor assistance for pickups. The successful bidder must arrange and perform all necessary transportation to ship, and/or remove the items. Property may be removed between the hours of 9:00 a.m. to 12:00 p.m. or 1:00 p.m. to 3:00 p.m. Monday through Friday, excluding State holidays.

Inquiries concerning the bidding process may be made to paula.eckard@faypwc.com, if you have prequalification or technical questions about the units offered, please contact elbert.norris@faypwc.com.

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu	Date O.S.	Co #	YMF#	2026
1	74AH17920	25	1-295-365	7200	120/240	N	CSP	420	Training Yard	<1.0	WH	1/6/26	012045	1974	52
2	87A500489	25	1-295-365	7200	120/240	N	CSP	420	Training Yard	<1.0	WH	1/6/26	87A500489	1987	39
3	G491533-66Y	25	1-295-365	7200	120/240	G	CSP	480		<1.0	GE	4/21/26	016458	1985	41
4	B0407937889	25	1-295-365	7200	120/240	G	CSP	488	2600351-02	<1.0	ER	9/23/25	041627	2004	22
5	71K2693	50	1-295-220	7200	240/120	G	URD	766	2313697-02	17.4	WH	12/3/25	016917	1971	55
6	86NB198-031	25	1-295-365	7200	120/240	G	CSP	430	2609155-01	<1.0	ME	3/13/26	023949	1986	40
7	71K2706	50	1-295-220	7200	240/120	G	URD	766	2313697-02	17	WH	12/3/25	016916	1971	55
8	84NB036-050	25	1-295-365	7200	120/240	G	CSP	415	2608425-02	<1.0	ME	3/21/26	022221	1984	42
9	84A041725	50	1-295-395	7200	120/240	G	CSP	705	2608425-02	<1.0	WH	3/21/26	022365	1984	42
10	74AJ6581	50	1-295-395	7200	120/240	G	CSP	649	2610189-01	<1.0	WH	4/15/26	003232	1974	52
11	74AB17823	15	1-295-355	14400	120/240	G	CSP	400	2507176-02	<1.0	WH	1/29/26	012200	1974	52
12	85A250912	50	1-295-395	7200	120/240	G	CSP	490	2608259-01	<1.0	WH	2/20/26	023352	1985	41
13	5042116	50	1-295-220	7200	240/120	G	URD	735	2609221-02	1.6	AC	3/23/26	016919	1950	76
14	5042111	50	1-295-220	7200	240/120	G	URD	735	2609221-02	<1.0	AC	3/23/26	016918	1950	76
15	00A433503	75	1-295-415	7200	120/240	G	CSP	836	2609942-01	<1.0	AB	4/6/26	037417	2000	26
16	00A433511	75	1-295-415	7200	120/240	G	CSP	836	2609942-01	<1.0	AB	4/6/26	037415	2000	26
17	00A433502	75	1-295-415	7200	120/240	G	CSP	836	2609942-01	<1.0	AB	4/6/26	037414	2000	26
18	0038026553	167	1-295-142	7200	120/240	G	Conv.	1778	2603816-02	<1.0	CP	4/9/26	036762	2000	26
19	80A221763	50	1-295-395	7200	120/240	G	CSP	500	2609884-01	<1.0	WH	4/2/26	043410	1980	46
20	94A264292	75	1-295-085	14.4x7.2	120/240	G	Conv.	887	2609488-01	<1.0	AB	3/23/26	031737	1994	32
21	Q361780-YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2607686-01	<1.0	GE	1/25/26	031538	1994	32
22	Q664764-YPL	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2600975-02	<1.0	GE	1/29/26	033361	1996	30
23	Q361684-YRJ	25	1-295-370	7.2x14.4	120/240	G	CSP	579	2600975-02	<1.0	GE	1/29/26	031536	1994	32
24	88A511641	25	1-295-370	7.2x14.4	120/240	N	CSP	500	2608416-01	<1.0	WH	2/16/26	025982	1988	38
25	48A5578614	25	1-295-370	7.2x14.4	120/240	G	CSP	410	2609486-01	<1.0	ER	3/22/26	034959	1997	29
26	871114956	25	1-295-370	7.2x14.4	120/240	G	CSP	480	2608760-02	<1.0	RT	3/18/26	024956	1987	39
27	30Y4383246	25	1-295-370	7.2x14.4	120/240	G	CSP	435	2607717-02	<1.0	ER	2/17/26	033012	1995	31
28	36V3204014	10	1-295-331	7.2x14.4	120/240	G	CSP	400	2606920-02	<1.0	ER	1/8/26	029122	1992	34
29	92NF184028	10	1-295-331	7.2x14.4	120/240	G	CSP	370	2608430-01	<1.0	CP	2/16/26	028766	1992	34
30	07W3377123	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2609844-02	<1.0	ER	4/9/26	029601	1993	33
31	A1309740707	25	1-295-380	14400	120/240	N	CSP	329	2608493-01	<1.0	ER	2/18/26	049460	2013	13
32	34W3528610	25	1-295-375	7.2x14.4	120	N	CSP	500	2608416-01	<1.0	ER	2/16/26	030151	1993	33
33	90107407797	10	1-295-330	7200	120/240	G	CSP	283	2606179-02	<1.0	ER	1/21/26	038848	2001	25
34	50107346289	10	1-295-330	7200	120/240	G	CSP	263	2606336-01	<1.0	ER	12/15/25	037791	2001	25
35	90207557182	10	1-295-330	7200	120/240	G	CSP	265	2603541-02	<1.0	ER	11/16/25	039788	2002	24
36	95NC285022	10	1-295-331	7.2x14.4	120/240	G	CSP	308	2607717-02	<1.0	CP	2/17/26	032558	1995	31
37	97NN612024	10	1-295-331	7.2x14.4	120/240	G	CSP	291	2609486-01	<1.0	CP	3/22/26	034750	1997	29
38	71AK17252	25	1-295-365	7200	120/240	G	CSP	486	2605577-02	3.4	WH	4/23/26	011200	1971	55
39	A2313448279	25	1-295-365	7200	120/240	G	CSP	460	FROM YARD	<1.0	ER	4/27/26	055064	2023	3
40	80207530377	15	1-295-365	7200	120/240	G	CSP	417	2606049-02	<1.0	ER	3/26/26	038362	2002	24
41	73AC11654	15	1-295-340	7200	120/240	G	CSP	380	2613392-01	<1.0	WH	6/9/26	015369	1973	53
42	64AE10400	15	1-295-340	7200	120/240	G	CSP	400	2611278-01	<1.0	WH	5/21/26	013742	1964	62
43	30L2819616	15	1-295-350	7.2x14.4	120/240	G	CSP	350	2610761-01	<1.0	WH	4/28/26	027930	1991	35
44	89NN108-026	50	1-295-400	7.2x14.4	120/240	G	CSP	650	2605166-02	<1.0	CM	6/3/26	026835	1989	37
45	M96L10450	10	1-295-331	7.2x14.4	120/240	G	CSP	400	2605084-02	<1.0	GE	5/28/26	033619	1996	30
46	40B6018923	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2610581-02	<1.0	ER	4/2/26	035673	1998	28
47	07W3377126	10	1-295-331	7.2x14.4	120/240	G	CSP	240	2503641-06	<1.0	ER	4/24/26	029620	1993	33
48	M949019VKRA	25	1-295-365	7200	120/240	G	CSP	369	2605077-02	<1.0	GE	5/18/26	018630	1994	32
49	M23H17865	25	1-295-365	7200	120/240	G	CSP	400	FROM YARD	<1.0	GE	6/23/26	055253	2023	3
50	20407783155	10	1-295-330	7200	120/240	G	CSP	272	2610004-01	<1.0	ER	4/8/26	041013	2004	22
51	891042437	5	1-295-321	7.2x14.4	120/240	G	CSP	310	2610945-02	<1.0	RT	6/10/26	026405	1989	37
52	C1610566939	25	1-295-380	14400	120/240	G	CSP	483	2602324-01	<1.0	ER	8/12/25	050722	2017	9
53	01S2079354	15	1-295-350	7.2x14.4	120/240	G	CSP	310	2610938-02	<1.0	ER	6/10/26	026177	2001	25
54	70908925036	10	1-295-330	7200	120/240	N	CSP	250	2613632-01	<1.0	AB	6/19/26	047012	2009	17
55	90A391629	25	1-295-370	7.2x14.4	120/240	G	CSP	380	2613599-01	<1.0	AB	6/18/26	027363	1990	36
56	93NN613008	10	1-295-331	7.2x14.4	120/240	G	CSP	380	2613522-02	<1.0	CP	6/18/26	030747	1993	33
57	B0708608166	25	1-295-365	7200	120/240	N	CSP	486	2610018-01	<1.0	ER	6/26/26	045830	2007	19
58	12011705662	50	1-295-395	7200	120/240	N	CSP	584	2613993-02	<1.0	ER	6/30/26	051209	2020	6
59	4226539906	25	1-295-375	7.2x14.4	120	G	CSP	480	2611782-01	<1.0	KU	6/8/26	036083	1998	28
60	M98K14743	50	1-295-400	7.2x14.4	120/240	G	CSP	768	2610746-01	<1.0	GE	4/27/26	036131	1998	28
61	4226539908	25	1-295-375	7.2x14.4	120	G	CSP	480	2611782-01	<1.0	KU	6/8/26	036087	1999	27
62	40Y4562301	25	1-295-375	7.2x14.4	120	G	CSP	410	2611782-01	<1.0	ER	6/8/26	033339	1995	31
63	71AH4071	25	1-295-365	7200	120/240	G	CSP	400	2613632-01	17.9	WH	6/19/26	011202	1971	55
64	42H650936	25	1-295-365	7200	120/240	G	CSP	400	2613505-01	<1.0	ER	6/14/26	021098	1982	44
65	68AJ6453	50	1-295-395	7200	120/240	G	CSP	400	2613632-01	<1.0	WH	6/19/26	012298	1968	58
66	38X3987569	10	1-295-331	7.2x14.4	120/240	G	CSP	300	2613632-01	<1.0	ER	6/18/26	031939	1994	32
67	4924688	25	1-295-365	7200	120/240	G	CSP	385	2610939-01	8.8	AC	5/7/26	006799	1969	57
68	73AL7419	50	1-295-395	7200	120/240	G	CSP	649	2610939-01	<1.0	WH	5/7/26	012280	1973	53
69	83NC018-050	50	1-295-395	7200	120/240	G	CSP	400	2611277-01	<1.0	ME	5/21/26	021379	1983	43
70	83NC018-044	50	1-295-395	7200	120/240	G	CSP	635	2611166-02	<1.0	ME	6/3/26	021360	1983	43
71	92A242898	25	1-295-370	7.2x14.4	120/240	G	CSP	450	2610745-02	<1.0	ME	5/8/26	028815	1992	34
72	4164399802	25	1-295-375	7.2x14.4	120	G	CSP	600	2611586-01	<1.0	KU	5/29/26	035381	1998	28
73	4164399805	25	1-295-375	7.2x14.4	120	G	CSP	600	2611586-01	<1.0	KU	5/29/26	035385	1998	28
74	4226539910	25	1-295-375	7.2x14.4	120	N	CSP	500	2608416-01	<1.0	KU	2/16/26	036096	1999	27
75	6597535	7.5	1-295-325	7200	120/240	G	CSP	300	2601808-02	<11.1	WH	9/4/25	007360	1965	61
Total KVA =		2279.5				Total Lbs=		36787					AVG=	35	

NO OIL

NO OIL

NO OIL

NO OIL

NO OIL

No.	Serial#	KVA	Stock Number	Pri voltage	Sec voltage	Work Cond	Type	weight	Work order	PPM	Manu	Date O.S.	Co #	YMF	2026
-----	---------	-----	--------------	-------------	-------------	-----------	------	--------	------------	-----	------	-----------	------	-----	------

Total Units >= 30 years 48
Total Units >=20 and <= 30 27
Total Units < 20 7
Total = 75

5 Kva total=	5
7.5 Kva total=	7.5
10 Kva total=	150
15 Kva total=	75
25 Kva total=	825
75 Kva total=	300
50 Kva total=	750
167 Kva total=	167
Total KVA	2279.5

Total# 5 Kva =	1
Total# 7.5 Kva =	1
Total# 10 Kva =	15
Total# 15 Kva =	5
Total# 25 Kva =	33
Total# 50 Kva =	15
Total# 75 Kva =	4
Total# 167 Kva =	1
Total	75

1-295-066	0
1-295-085	1
1-295-142	1
1-295-220	4
1-295-321	1
1-295-325	1
1-295-330	5
1-295-331	10
1-295-340	2
1-295-350	2
1-295-355	1
1-295-365	15
1-295-370	9
1-295-375	7
1-295-380	2
1-295-395	9
1-295-400	2
1-295-415	3
Total# Units	75

N
G
Total Bad Unit= 9
Total Operational Units= 66
Total= 75

Mfg Totals		
	AC	3
	ABB	6
	COOPER	5
	ERMCO	24
	GE	8
	HOWARD	0
	KUHLMAN	5
	McGraw-Edison	4
	RTE	2
	WEST	17
	Central-Moloney	1
Total=		75

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	74AH17920	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	01/28/2026				
Barcode Sample Number	00316564				
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

2

Nameplate Data				Equipment Information	
Serial Number	87A500489	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 01/28/2026					
Barcode Sample Number 00316560					
PCB (D4059) ppm < 1					
Oil Quality Fluid test has No PCB.					

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

3

Nameplate Data				Equipment Information	
Serial Number	G491533-66Y	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/22/2026
Barcode Sample Number	00316498
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

4

Nameplate Data				Equipment Information	
Serial Number	B0407937889	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	01/28/2026				
Barcode Sample Number	00316565				
PCB (D4059)	ppm	< 1			
Oil Quality		Fluid test has No PCB.			

7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

5

Nameplate Data				Equipment Information	
Serial Number	71K2693	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316539	
PCB (D4059)	ppm	17.4
Oil Quality	Fluid test as Non-PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

6

Nameplate Data				Equipment Information	
Serial Number	86NB198-031	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	McGraw Edison	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		04/01/2026
Barcode Sample Number		00316524
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

7

Nameplate Data				Equipment Information	
Serial Number	71K2706	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date 03/04/2026					
Barcode Sample Number 00316538					
PCB (D4059) ppm 17.0					
Oil Quality Fluid test as Non-PCB.					

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

8

Nameplate Data				Equipment Information	
Serial Number	84NB036-050	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	McGraw Edison	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation Location	Apparatus	Breathing Configuration			

Sample Date		04/01/2026
Barcode Sample Number		00316515
PCB (D4059)	ppm	< 1
Oil Quality		Fluid test has No PCB.

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

9

Nameplate Data				Equipment Information	
Serial Number	84A041725	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Westinghouse	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date		04/01/2026			
Barcode Sample Number		00316514			
PCB (D4059)		ppm	< 1		
Oil Quality		Fluid test has No PCB.			

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	74AJ6581	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date	04/22/2026	
Barcode Sample Number	00316497	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	74AB17823	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316547	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

12

Nameplate Data				Equipment Information	
Serial Number	85A250912	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316529	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

13

Nameplate Data				Equipment Information	
Serial Number	5042116	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Allis Chalmers	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		04/01/2026			
Barcode Sample Number		00316510			
PCB (D4059)	ppm	1.6			
Oil Quality	Fluid test as Non-PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

14

Nameplate Data				Equipment Information	
Serial Number	5042111	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Allis Chalmers	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		04/01/2026
Barcode Sample Number		00316511
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	00A433503	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	75	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/22/2026	
Barcode Sample Number	00316501	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	00A433511	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	75	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/22/2026		
Barcode Sample Number	00316499		
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	00A433502	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	75	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		04/22/2026			
Barcode Sample Number		00316500			
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	0038026553	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	167	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/22/2026	
Barcode Sample Number	00316504	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	80A221763	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/22/2026		
Barcode Sample Number	00316502		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

20

Nameplate Data				Equipment Information	
Serial Number	94A264292	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	ABB	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	75	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/01/2026	
Barcode Sample Number	00316516	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

21

Nameplate Data				Equipment Information	
Serial Number	Q361780-YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316549	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

22

Nameplate Data				Equipment Information	
Serial Number	Q664764-YPL	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026		
Barcode Sample Number	00316550		
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	Q361684-YRJ	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316548	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	88A511641	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026		
Barcode Sample Number	00316537		
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	48A5578614	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	ERMCO	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/01/2026	
Barcode Sample Number	00316523	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	871114956	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Other	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		04/01/2026	
Barcode Sample Number		00316526	
PCB (D4059)	ppm	< 1	
Oil Quality		Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data			
Serial Number	30Y4383246	Unit ID	OH
Equipment Type	Transformer	Manufacturer	
Year Manufactured		Primary KV	
Gallons		KVA Rating	25
Phases	1	Fluid type	Mineral Oil
Substation		Breathing	
Location	Apparatus	Configuration	

Equipment Information	
Top Valve (in)	Bottom Valve (in)
Hose Length (ft)	Paint Condition
Conservator Tank	Bushings Enclosed
Leaks	Radiators
Service Energized	Compartments

Sample Date	03/04/2026
Barcode Sample Number	00316532
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

28

Nameplate Data				Equipment Information	
Serial Number	36V3204014	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316552	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	92NF184028	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026		
Barcode Sample Number	00316534		
PCB (D4059)	ppm	< 1	
Oil Quality	Fluid test has No PCB.		

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

30

Nameplate Data				Equipment Information	
Serial Number	07W3377123	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/22/2026	
Barcode Sample Number	00316503	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

31

Nameplate Data				Equipment Information	
Serial Number	A1309740707	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date	03/04/2026				
Barcode Sample Number	00316531				
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	34W3528810	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316535	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	90107407797	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	ERMCO	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date		04/01/2026
Barcode Sample Number		00316527
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

34

Nameplate Data				Equipment Information	
Serial Number	50107346289	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316546	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

35

Nameplate Data				Equipment Information	
Serial Number	90207557182	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	01/28/2026	
Barcode Sample Number	00316567	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	95NC285022	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026	
Barcode Sample Number	00316533	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

37

Nameplate Data				Equipment Information	
Serial Number	97NN812024	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer	Cooper	Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	04/01/2026	
Barcode Sample Number	00316522	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

38

Nameplate Data				Equipment Information	
Serial Number	71AK17252	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		06/30/2026
Barcode Sample Number		00386490
PCB (D4059)	ppm	3.4
Oil Quality	Fluid test as Non-PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	A2313448279	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386488	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	80207530377	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386487	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	73AC11654	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386483	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

42

Nameplate Data				Equipment Information	
Serial Number	64AE10400	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026				
Barcode Sample Number	00386505				
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	30U2819616	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00316483	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	89NN108-026	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation	Apparatus	Breathing			
Location		Configuration			

Sample Date		06/30/2026
Barcode Sample Number		00386495
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	M96L10450	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386497	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	40B6018923	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00316479	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	07W3377126	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386492	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

48

Nameplate Data				Equipment Information	
Serial Number	M949019YKRA	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386498	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	M23H17865	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026				
Barcode Sample Number	00386405				
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

49

7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

50

Nameplate Data				Equipment Information	
Serial Number	20407783155	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		07/16/2026
Barcode Sample Number		00386395
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	891042437	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	5	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386309	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	C1610566939	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386385	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	01S2079354	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	15	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386308	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	70908925036	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386398	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	90A391629	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386396	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	93NN613008	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386397	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	B0708609166	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		07/16/2026
Barcode Sample Number		00386400
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	12011705662	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386399	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	4226539906	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386484	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	M98K14743	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386493	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	4226539908	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386485	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	49Y4562301	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386486	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

4588 Faircrest St SW, Canton, OH 44706

p: 330.498.6255 | f: 330.498.6261

www.mvadiagnostics.com

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	71AH4071	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		07/16/2026			
Barcode Sample Number		00386389			
PCB (D4059)	ppm	17.9			
Oil Quality	Fluid test as Non-PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	42H650936	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386388	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	68AJ6453	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026				
Barcode Sample Number	00386391				
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	38X3987569	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	10	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	07/16/2026	
Barcode Sample Number	00386390	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

#711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

67

Nameplate Data				Equipment Information	
Serial Number	4924688	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026		
Barcode Sample Number	00316480		
PCB (D4059)	ppm	8.8	
Oil Quality	Fluid test as Non-PCB.		

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	73AL7419	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00316481	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	83NC018-050	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date		06/30/2026			
Barcode Sample Number		00386499			
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	83NC018-044	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	50	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date		06/30/2026			
Barcode Sample Number		00386496			
PCB (D4059)	ppm	< 1			
Oil Quality	Fluid test has No PCB.				

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	92A242898	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00316484	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

7110H



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	4184399802	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	06/30/2026	
Barcode Sample Number	00386502	
PCB (D4059)	ppm	< 1
Oil Quality	Fluid test has No PCB.	

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	4184399805	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			
Sample Date		06/30/2026			
Barcode Sample Number		00386504			
PCB (D4059)	ppm	< 1			
Oil Quality		Fluid test has No PCB.			

711 041



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	4226539910	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	25	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	03/04/2026
Barcode Sample Number	00316536
PCB (D4059)	ppm < 1
Oil Quality	Fluid test has No PCB.

711 OH



Fayetteville Public Works
Commission (Apparatus)
955 Old Wilmington Rd
Fayetteville, NC, 28302-1089

Nameplate Data				Equipment Information	
Serial Number	6597535	Unit ID	OH	Top Valve (in)	Bottom Valve (in)
Equipment Type	Transformer	Manufacturer		Hose Length (ft)	Paint Condition
Year Manufactured		Primary KV		Conservator Tank	Bushings Enclosed
Gallons		KVA Rating	7.5	Leaks	Radiators
Phases	1	Fluid type	Mineral Oil	Service Energized	Compartments
Substation		Breathing			
Location	Apparatus	Configuration			

Sample Date	10/03/2025	
Barcode Sample Number	00316746	
PCB (D4059)	ppm	11.1
Oil Quality	Fluid test as Non-PCB.	



Surplus Transformer Shipment Lot 711

Due October 29, 2026

PWC2627020Bid Pricing Form

Bidders Information

Bidders Name: _____

Street Address: _____

Telephone Number: _____

Email: _____

Print Name and Title: _____

Bidders Authorized Signature: _____

Date: _____

Pricing

LOT	QTY (LOT KVA TOTAL)	UNIT COST	EXTENDED COST
711	2279.5		