



FAYETTEVILLE PUBLIC WORKS COMMISSION

PROCUREMENT DEPARTMENT

<https://www.faypwc.com/bids/>

Bid Addendum

PWC Number: PWC2627016

Bid Title: STEEL POLES FOR DUKE ENERGY TAP LINE FOR POD V

Bid Opening Date and Time: October 15, 2026, 2:00 p.m.

Addendum Number: 4

Addendum Date: October 7, 2026

Procurement Advisor: *Nikole Bohannon or Candice Kirtz*
procurement@faypwc.com

1. Addenda acknowledgement is required within the IFB Bid Pricing Form.
2. The solicitation is hereby modified as follows:

M1. IFB Schedule Modified

Addendum Deadline issued by PWC: October 7, 2026, at 5:00 p.m.

M2. Sales and Use Tax Clarification.

Bid pricing submitted on **Attachment B: Bid Pricing Form** shall be exclusive of applicable North Carolina sales and use tax. Sales and use tax shall not be included in unit prices, extended prices, or the Total Bid Price. All other costs shall remain included as required by the IFB. Applicable North Carolina sales and use tax will be added to the awarded bid price, as applicable, for purposes of establishing the total Sale of Goods Agreement amount.

3. Following are questions received about the solicitation and the SME's answers to the questions.

Q1. Since the bid date got pushed out until oct 15, it appears that for the embedded part of the H series, poles are to be non-tapered. The first section above grade would be tapered and welded in our shop around the sleeve shown on the drawings. Please advise.

A1. The poles are to be tapered throughout the length, uniformly.